

NO: WRD /WD XI / SD III/ TECH/W.F.45 -2022/165 / 2023-24.

Dated:27/06/2023

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Open Type Bandhara in Sy.No. 142 at Shiroti Khola Village of Canacona Taluka in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.45/06/2022						231.11		No. WRD/SD V/WD XII/ F.70/46/2023-24. DATED: 19-05-2023.
	F.45/07/2022	2/5/2023	30-05-2023	Down Stream Cutoff	1.2.4	210 kg/cm2	226.67	231.11	
	F.45/08/2022						235.56		
1.2	F.45/09/2022						231.11		do
	F.45/10/2022	2/5/2023	30-05-2023	Down Stream Cutoff	1.2.4	210 kg/cm2	231.11	229.63	
	F.45/11/2022						226.67		
2.1	F.45/12/2022						235.56		do
	F.45/13/2022	4/5/2023	1/6/2023	Upstream Cutoff	1.2.4	210 kg/cm2	231.11	232.59	
	F.45/14/2022						231.11		
2.2	F.45/15/2022						231.11		do
	F.45/16/2022	4/5/2023	1/6/2023	Upstream Cutoff	1.2.4	210 kg/cm2	222.22	228.15	
	F.45/17/2022						231.11		
3.1	F.45/18/2022						226.67		do
	F.45/19/2022	8/5/2023	5/6/2023	Centre Cutoff	1.2.4	210 kg/cm2	222.22	226.67	
	F.45/20/2022						231.11		
3.2	F.45/21/2022						226.67		do
	F.45/22/2022	8/5/2023	5/6/2023	Centre Cutoff	1.2.4	210 kg/cm2	231.11	228.15	
	F.45/23/2022						226.67		
4.1	F.45/24/2022						288.89		do
	F.45/25/2022	13-05-2023	10/6/2023	Raft	1.1.5.3	265 kg/cm2	293.33	288.89	
	F.45/26/2022						284.44		
4.2	F.45/27/2022						288.89		do
	F.45/28/2022	13-05-2023	10/6/2023	Raft	1.1.5.3	265 kg/cm2	297.78	293.33	
	F.45/29/2022						293.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of Open Type Bandhara in Sy.No. 142 at Shiroti Khola Village of Canacona Taluka in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.3	F.45/30/2022						293.33		No. WRD/SD V/WD XII/ F.70/46/2023-24. DATED: 19-05-2023.
	F.45/31/2022	13-05-2023	10/6/2023	Raft	1.1.5.3	265 kg/cm2	288.89	291.85	
	F.45/32/2022						293.33		
4.4	F.45/33/2022						297.78		
	F.45/34/2022	13-05-2023	10/6/2023	Raft	1.1.5.3	265 kg/cm2	293.33	291.85	do
	F.45/35/2022						284.44		
5.1	F.45/36/2022						222.22		
	F.45/37/2022	15-05-2023	12/6/2023	Apron U/s	1.2.4	210 kg/cm2	231.11	226.67	do
	F.45/38/2022						226.67		
5.2	F.45/39/2022						226.67		
	F.45/40/2022	15-05-2023	12/6/2023	Apron U/s	1.2.4	210 kg/cm2	226.67	228.15	do
	F.45/41/2022						231.11		
5.3	F.45/42/2022						231.11		
	F.45/43/2022	15-05-2023	12/6/2023	Apron U/s	1.2.4	210 kg/cm2	226.67	229.63	do
	F.45/44/2022						231.11		
5.4	F.45/45/2022						222.22		
	F.45/46/2022	15-05-2023	12/6/2023	Apron U/s	1.2.4	210 kg/cm2	226.67	225.19	do
	F.45/47/2022						226.67		
6.1	F.45/48/2022						235.56		
	F.45/49/2022	17-05-2023	14-06-2023	Apron U/s	1.2.4	210 kg/cm2	222.22	229.63	do
	F.45/50/2022						231.11		
6.2	F.45/51/2022						226.67		
	F.45/52/2022	17-05-2023	14-06-2023	Apron U/s	1.2.4	210 kg/cm2	231.11	231.11	do
	F.45/53/2022						235.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER