

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Protection wall for hillock adjoining Chalta No. 220 of P.T. Sheet No. 3 at Aquem of Margao City.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	1058						164.44		No. W.F.259/SD III/WD III/ WRD/2020-21/332 DATED: 13-01-2021
	1059	8/1/2021	5/2/2021	In Foundation	1.2.4	150 kg/cm2	160.00	161.48	
	1060						160.00		
2	1061						164.44		do
	1062	12/1/2021	9/2/2021	In 1st Lift 0.00m to 10.20 m	1.2.4	150 kg/cm2	160.00	161.48	
	1063						160.00		
3	1487						160.00		No. W.F.259/SD III/WD III/ WRD/2020-21/347 DATED: 27-01-2021
	1488	21-01-2021	18-02-2021	In 2nd Lift 0.00 m to 10.20 m	1.2.4	150 kg/cm2	164.44	162.96	
	1489						164.44		
4	1490						164.44		do
	1491	22-01-2021	19-02-2021	In 1st Lift 10.20 m to 17.25 m	1.2.4	150 kg/cm2	164.44	164.44	
	1492						164.44		
5	1493						164.44		do
	1494	25-01-2021	22-02-2021	In 2nd Lift 10.20 m to 17.25 m	1.2.4	150 kg/cm2	160.00	162.96	
	1495						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER