

NO: WRD /WD XI / SD III/ TECH/W.F. 131-2021/03 / 2022-23

Dated:28/07/2022

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah near VPHK Society behind Good Shepherd hotel at Rawanfond Margao- Goa.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

| REPORT NO | SAMPLE NOS. | CASTING DATE | TESTING DATE | LOCATION OF SAMPLE | MIX PROPORTION | REQUIRED STRENGTH | Comp sth in Kg/cm2 | Avg. Comp Kg/cm2 | LETTER No / DATED |
|-----------|---------------|--------------|--------------|-----------------------------------|----------------|-------------------|--------------------|------------------|---|
| 1 | F.131/71/2021 | | | | | | 160.00 | | No.304/SD III/ WD III/ WRD/ 2022-23/156. DATED:- 18-07-2022. |
| | F.131/72/2021 | 11/7/2022 | 18-07-2022 | Foundation block Ch. 110 to 121 m | 1.2.4 | 140 kg/cm2 | 160.00 | 158.52 | |
| | F.131/73/2021 | | | | | | 155.56 | | |
| 2 | F.131/74/2021 | | | | | | 156.56 | | do |
| | F.131/75/2021 | 13-07-2022 | 20-07-2022 | Above Foundation Ch. 110 to 121 m | 1.2.4 | 140 kg/cm2 | 160.00 | 157.37 | |
| | F.131/76/2021 | | | | | | 155.56 | | |
| 3.1 | F.131/77/2021 | | | | | | 160.00 | | do |
| | F.131/78/2021 | 13-07-2022 | 20-07-2022 | 2nd lift Ch. 0 to 55 mt | 1.2.4 | 140 kg/cm2 | 160.00 | 157.04 | |
| | F.131/79/2021 | | | | | | 151.11 | | |
| 3.2 | F.131/80/2021 | | | | | | 155.56 | | do |
| | F.131/81/2021 | 13-07-2022 | 20-07-2022 | 2nd lift Ch. 0 to 55 mt | 1.2.4 | 140 kg/cm2 | 155.56 | 155.56 | |
| | F.131/82/2021 | | | | | | 155.56 | | |
| 4.1 | F.131/83/2021 | | | | | | 160.00 | | do |
| | F.131/84/2021 | 16-07-2022 | 23-07-2022 | 2nd lift Ch. 55 to 110 mt | 1.2.4 | 140 kg/cm2 | 151.11 | 157.04 | |
| | F.131/85/2021 | | | | | | 160.00 | | |
| 4.2 | F.131/86/2021 | | | | | | 155.56 | | do |
| | F.131/87/2021 | 16-07-2022 | 23-07-2022 | 2nd lift Ch. 55 to 110 mt | 1.2.4 | 140 kg/cm2 | 151.11 | 155.56 | |
| | F.131/88/2021 | | | | | | 160.00 | | |

JUNIOR ENGINEER.

ASSISTANT ENGINEER