

NO: WRD /WD XI / SD III/ TECH/W.F. 131-2021/05 / 2022-23

Dated:06/08/2022

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah near VPHK Society behind Good Shepherd hotel at Rawanfond Margao- Goa.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.131/36/2021						235.56		No.304/SD III/ WD III/ WRD/ 2022-23/150. DATED:- 14-07-2022.
	F.131/37/2021	20-06-2022	18-07-2022	1st Lift Ch.0 to 35 m	1.2.4	210 kg/cm2	235.56	237.04	
	F.131/38/2021						240.00		
1.2	F.131/39/2021						240.00		do
	F.131/40/2021	20-06-2022	18-07-2022	1st Lift Ch.0 to 35 m	1.2.4	210 kg/cm2	244.44	241.48	
	F.131/41/2021						240.00		
1.3	F.131/42/2021						235.56		do
	F.131/43/2021	20-06-2022	18-07-2022	1st Lift Ch.0 to 35 m	1.2.4	210 kg/cm2	231.11	238.52	
	F.131/44/2021						248.89		
1.4	F.131/45/2021						240.00		do
	F.131/46/2021	20-06-2022	18-07-2022	1st Lift Ch.0 to 35 m	1.2.4	210 kg/cm2	231.11	237.04	
	F.131/47/2021						240.00		
2.1	F.131/48/2021						235.56		do
	F.131/49/2021	27-06-2022	25-07-2022	1st Lift Ch. 35 to 70 m	1.2.4	210 kg/cm2	235.56	235.56	
	F.131/50/2021						235.56		
2.2	F.131/50/2021						240.00		do
	F.131/51/2021	27-06-2022	25-07-2022	1st Lift Ch. 35 to 70 m	1.2.4	210 kg/cm2	231.11	237.04	
	F.131/52/2021						240.00		
2.3	F.131/53/2021						240.00		do
	F.131/54/2021	27-06-2022	25-07-2022	1st Lift Ch. 35 to 70 m	1.2.4	210 kg/cm2	235.56	235.56	
	F.131/55/2021						231.11		
2.4	F.131/56/2021						235.56		do
	F.131/57/2021	27-06-2022	25-07-2022	1st Lift Ch. 35 to 70 m	1.2.4	210 kg/cm2	235.56	237.04	
	F.131/58/2021						240.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah near VPHK Society behind Good Shepherd hotel at Rawanfond Margao- Goa.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.1	F.131/59/2021						235.56		No.304/SD III/ WD III/
	F.131/60/2021	4/7/2022	1/8/2022	1st Lift Ch. 70 to 110 m	1.2.4	210 kg/cm2	235.56	235.56	WRD/ 2022-23/150.
	F.131/61/2021						235.56		DATED:- 14-07-2022.
3.2	F.131/62/2021						240.00		
	F.131/63/2021	4/7/2022	1/8/2022	1st Lift Ch. 70 to 110 m	1.2.4	210 kg/cm2	231.11	237.04	do
	F.131/64/2021						240.00		
3.3	F.131/65/2021						240.00		
	F.131/66/2021	4/7/2022	1/8/2022	1st Lift Ch. 70 to 110 m	1.2.4	210 kg/cm2	235.56	235.56	do
	F.131/67/2021						231.11		
3.4	F.131/68/2021						235.56		
	F.131/69/2021	4/7/2022	1/8/2022	1st Lift Ch. 70 to 110 m	1.2.4	210 kg/cm2	235.56	237.04	do
	F.131/70/2021						240.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER