

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Providing RCC Canal Lining to Minor M1 Canal from Ch 2400 to 2980 mts in Cacora Village of Quepem Taluka.

SAMPLE SENT BY: AE, SD I, WD X, WRD, Quepem-Goa.

NAME OF THE AGENCY : M/s Ashko Builders, Navelim, Goa.

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
	91						106.67		No. WRD/WD X
1	92	06-11-2019	04-12-2019	50mm PCC below RCC Canal lining.	1.3.6	100 kg/cm2	106.67	108.15	/SD I/F.10/142/
	93						111.11		2019-20
	94						111.11		Dt.11/11/2019
2	95	07-11-2019	04-12-2019	50mm PCC below RCC Canal lining.	1.3.6	100 kg/cm2	111.11	109.63	do
	96						106.67		
	97						111.11		
3	98	08-11-2019	05-12-2019	50mm PCC below RCC Canal lining.	1.3.6	100 kg/cm2	106.67	109.63	do
	99						111.11		

TECHNICAL ASSISTANT
(Dhananjay R. Nagvenkar)

ASSISTANT ENGINEER
(Pravin C. Parsekar)

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Providing RCC Canal Lining to Minor M1 Canal from Ch 2400 to 2980 mts in Cacora Village of Quepem Taluka.

SAMPLE SENT BY: AE, SD I, WD X, WRD, Quepem-Goa.

NAME OF THE AGENCY : M/s Ashko Builders, Navelim, Goa.

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
	280						111.11		No. WRD/WD X
1	281	09-11-2019	06-12-2019	50mm PCC below RCC Canal lining.	1.3.6	100 kg/cm2	111.11	111.11	/SD I/F.10/144/
	282						111.11		2019-20
	283						106.67		Dt.13/11/2019
2	284	10-11-2019	07-12-2019	50mm PCC below RCC Canal lining.	1.3.6	100 kg/cm2	106.67	108.15	do
	285						111.11		
	286						106.67		
3	287	11-11-2019	09-12-2019	50mm PCC below RCC Canal lining.	1.3.6	100 kg/cm2	111.11	108.15	do
	288						106.67		

TECHNICAL ASSISTANT
(Dhananjay R. Nagvenkar)

ASSISTANT ENGINEER
(Pravin C. Parsekar)