

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Anti Sea Erosion Wall from Vinod Sawant house to Audumbar Sirsaikar house in V.P Assagao in Siolim Constituency.

SAMPLE SENT BY: AE, SD I, WD I, WRD, Porvorim-Goa.

NAME OF THE AGENCY : Ashko Builders, H.no. 360,Dyna Soda Factory second Dandio, Talaulim, Nav

TESTING PERIOD 28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
	1541						226.67		No. SDI/WD I/ WRD/
1	1542	20-12-2019	17-01-2019	Fundation & Plinth	1.2.4	210 kg/cm2	226.67	225.19	F.57/19-20/355
	1543						222.22		Dt.26/12/2019
	1544						222.22		
2	1545	20-12-2019	17-01-2019	Fundation & Plinth	1.2.4	210 kg/cm2	222.22	223.70	do
	1546						226.67		
	1547						226.67		
3	1548	20-12-2019	17-01-2019	Fundation & Plinth	1.2.4	210 kg/cm2	222.22	225.19	do
	1549						226.67		
	1547						231.11		
4	1548	20-12-2019	17-01-2019	Fundation & Plinth	1.2.4	210 kg/cm2	231.11	229.63	do
	1549						226.67		
	1547						226.67		
5	1548	21-12-2019	18-01-2020	Fundation & Plinth	1.2.4	210 kg/cm2	226.67	228.15	do
	1549						231.11		
	1547						222.22		
6	1548	21-12-2019	18-01-2020	Fundation & Plinth	1.2.4	210 kg/cm2	231.11	226.67	do
	1549						226.67		
	1547						226.67		
7	1548	21-12-2019	18-01-2020	Fundation & Plinth	1.2.4	210 kg/cm2	226.67	228.15	do
	1549						231.11		
	1547						226.67		
8	1548	21-12-2019	18-01-2020	Fundation & Plinth	1.2.4	210 kg/cm2	226.67	226.67	do
	1549						226.67		

TECHNICAL ASSISTANT
(Dhananjay R. Nagvenkar)

ASSISTANT ENGINEER
(Pravin C. Parsekar)

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Anti Sea Erosion Wall from Vinod Sawant house to Audumbar Sirsaikar house in V.P Assagao in Siolim Constituency.

SAMPLE SENT BY: AE, SD I, WD I, WRD, Porvorim-Goa.

NAME OF THE AGENCY : Ashko Builders, H.no. 360,Dyna Soda Factory second Dandio, Talaulim, Nav

TESTING PERIOD 28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
	1550						226.67		No. SDI/WD I/ WRD/
1	1551	23-12-2019	20-01-2019	Foundation & Plinth	1.2.4	210 kg/cm2	231.11	228.15	F.57/19-20/355
	1552						226.67		Dt.26/12/2019
	1553						226.67		
2	1554	23-12-2019	20-01-2019	Foundation & Plinth	1.2.4	210 kg/cm2	226.67	226.67	do
	1555						226.67		
	1556						231.11		
3	1557	23-12-2019	20-01-2019	Foundation & Plinth	1.2.4	210 kg/cm2	226.67	228.15	do
	1558						226.67		
	1559						222.22		
4	1560	23-12-2019	20-01-2019	Foundation & Plinth	1.2.4	210 kg/cm2	226.67	225.19	do
	1561						226.67		

TECHNICAL ASSISTANT
(Dhananjay R. Nagvenkar)

ASSISTANT ENGINEER
(Pravin C. Parsekar)

