

NO.WRD/WDXI/SDIII/TECH/W.F.122/2024/2025-26/100

Dated:-9/5/2025

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Repairs and Beautification of lake at Nonu's house at Haldanwada in ward No. 05 of V.P. Betqui Candola in Priol Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.122/06/2024						231.11		No. WRD/WD XI/ SD IV/
	F.122/07/2024	10/4/2025	8/5/2025	For Foundation	1.2.4	210 kg/cm2	226.67	228.15	W.F. 620/32/2025-26.
	F.122/08/2024						226.67		DATED: 15-04-2025.
1.2	F.122/09/2024						231.11		
	F.122/10/2024	10/4/2025	8/5/2025	For Foundation	1.2.4	210 kg/cm2	222.22	225.18	do
	F.122/11/2024						222.22		
2.1	F.122/12/2024						235.56		
	F.122/13/2024	11/4/2025	9/5/2025	For Foundation	1.2.4	210 kg/cm2	226.67	229.63	do
	F.122/14/2024						226.67		
2.2	F.122/15/2024						240.00		
	F.122/16/2024	11/4/2025	9/5/2025	For Foundation	1.2.4	210 kg/cm2	226.67	226.67	do
	F.122/17/2024						213.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER