

NO.WRD/WDXI/SDIII/TECH/W.F.123/2024/2025-26/ 104

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

Dated:-13/05/2025

NAME OF THE WORK: Improvement of the tank near Deo Mahadeo Sy.No. 30/2 in Ward No. 02 of Sateribhat Volvoi in Priol Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.123/06/2024						231.11		No. WRD/WD XI/ SD IV/
	F.123/07/2024	9/4/2025	7/5/2025	For Foundation	1.2.4	210 kg/cm2	222.22	226.67	W.F. 590/33/2025-26.
	F.123/08/2024						226.67		DATED: 15-04-2025.
1.2	F.123/09/2024						235.56		
	F.123/10/2024	9/4/2025	7/5/2025	For Foundation	1.2.4	210 kg/cm2	226.67	229.63	do
	F.123/11/2024						226.67		
2.1	F.123/12/2024						231.11		
	F.123/13/2024	11/4/2025	9/5/2025	For Foundation	1.2.4	210 kg/cm2	226.67	228.15	do
	F.123/14/2024						226.67		
2.2	F.123/15/2024						240.00		
	F.123/16/2024	11/4/2025	9/5/2025	For Foundation	1.2.4	210 kg/cm2	226.67	231.11	do
	F.123/17/2024						226.67		
3.1	F.123/18/2024						235.56		
	F.123/19/2024	15-04-2024	13-05-2025	For Foundation	1.2.4	210 kg/cm2	226.67	228.15	do
	F.123/20/2024						222.22		
3.2	F.123/21/2024						231.11		
	F.123/22/2024	15-04-2024	13-05-2025	For Foundation	1.2.4	210 kg/cm2	231.11	229.63	do
	F.123/23/2024						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER