

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of protection wall near Dr. Gudinho house near Holy Spirit Church at Modsai in Fatorda Constituency.

**SAMPLE SENT BY:** AE, SD III, WD III, WRD, Gogol- Margao- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

**28 days.**

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.171/05/2023						231.11		No. 338/ SD III/ WD III/ WRD/24-25/82 <b>DATED: 07-06-2024</b>
	F.171/06/2023	10/5/2024	7/6/2024	Fdn block from Ch. 0 to 25m	1.2.4	210 kg/cm2	231.11	229.63	
	F.171/07/2023						226.67		
1.2	F.171/08/2023						235.56		
	F.171/09/2023	10/5/2024	7/6/2024	Fdn block from Ch. 0 to 25m	1.2.4	210 kg/cm2	226.67	228.15	do
	F.171/10/2023						222.22		
1.3	F.171/11/2023						231.11		
	F.171/12/2023	10/5/2024	7/6/2024	Fdn block from Ch. 0 to 25m	1.2.4	210 kg/cm2	217.78	226.67	do
	F.171/13/2023						231.11		
2.1	F.171/14/2023						231.11		
	F.171/15/2023	15-05-2024	12/6/2024	Retaining wall 1st lift step from	1.2.4	210 kg/cm2	226.67	228.15	do
	F.171/16/2023			Ch. 0 to 25 m			226.67		
2.2	F.171/17/2023						235.56		
	F.171/18/2023	15-05-2024	12/6/2024	Retaining wall 1st lift step from	1.2.4	210 kg/cm2	226.67	225.19	do
	F.171/19/2023			Ch. 0 to 25 m			213.33		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of protection wall near Dr. Gudinho house near Holy Spirit Church at Modsai in Fatorda Constituency.

**SAMPLE SENT BY:** AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
2.3	F.171/20/2023						235.56		No. 338/ SD III/ WD III/ WRD/24-25/82 <b>DATED: 07-06-2024</b>
	F.171/21/2023	15-05-2024	12/6/2024	Retaining wall 1st lift step from	1.2.4	210 kg/cm2	217.78	226.67	
	F.171/22/2023			Ch. 0 to 25 m			226.67		
2.4	F.171/23/2023						226.67		
	F.171/24/2023	15-05-2024	12/6/2024	Retaining wall 1st lift step from	1.2.4	210 kg/cm2	231.11	228.15	do
	F.171/25/2023			Ch. 0 to 25 m			226.67		
3.1	F.171/26/2023						231.11		
	F.171/27/2023	21-05-2024	18-06-2024	Retaining wall 2nd lift step from	1.2.4	210 kg/cm2	222.22	229.63	do
	F.171/28/2023			Ch. 0 to 25 m			235.56		
3.2	F.171/29/2023						231.11		
	F.171/30/2023	21-05-2024	18-06-2024	Retaining wall 2nd lift step from	1.2.4	210 kg/cm2	226.67	226.67	do
	F.171/31/2023			Ch. 0 to 25 m			222.22		
3.3	F.171/32/2023						235.56		
	F.171/33/2023	21-05-2024	18-06-2024	Retaining wall 2nd lift step from	1.2.4	210 kg/cm2	231.11	229.63	do
	F.171/34/2023			Ch. 0 to 25 m			222.22		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**