

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall in Sy.No. 152/2 for the Stablization of nallah bank at Village Talvorda, Cuncolim Constituency.

SAMPLE SENT BY: AE, SD III, WD II, WRD, Fatorda - Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F. 138/05/2024						235.56		No. WRD/SD III/ WD II/ F. 77/21/2025-26. DATED: 15-04-2025.
	F. 138/06/2024	10/4/2025	8/5/2025	Foundation	1.2.4	210 kg/cm2	226.67	228.15	
	F. 138/07/2024						222.22		
1.2	F. 138/08/2024						235.56		do
	F. 138/09/2024	10/4/2025	8/5/2025	Foundation	1.2.4	210 kg/cm2	226.67	229.63	
	F. 138/10/2024						226.67		
1.3	F. 138/11/2024						231.11		do
	F. 138/12/2024	10/4/2025	8/5/2025	Foundation	1.2.4	210 kg/cm2	226.67	231.11	
	F. 138/13/2024						235.56		
2.1	F. 138/14/2024						231.11		do
	F. 138/15/2024	12/4/2025	12/4/2025	Wall	1.2.4	210 kg/cm2	217.78	225.19	
	F. 138/16/2024						226.67		
2.2	F. 138/17/2024						235.56		do
	F. 138/18/2024	12/4/2025	12/4/2025	Wall	1.2.4	210 kg/cm2	217.78	226.67	
	F. 138/19/2024						226.67		
2.3	F. 138/20/2024						231.11		do
	F. 138/21/2024	12/4/2025	12/4/2025	Wall	1.2.4	210 kg/cm2	222.22	225.18	
	F. 138/22/2024						222.22		
3.1	F. 138/23/2024						231.11		do
	F. 138/24/2024	14-04-2025	12/5/2025	Wall	1.2.4	210 kg/cm2	222.22	226.67	
	F. 138/25/2024						226.67		
3.2	F. 138/26/2024						231.11		do
	F. 138/27/2024	14-04-2025	12/5/2025	Wall	1.2.4	210 kg/cm2	231.11	228.15	
	F. 138/28/2024						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER