

NO.WRD/WDXI/SDIII/TECH/W.F.172/2023/2024-25/109

. Dated:-19/06/24

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Urgent Construction of retaining wall to retain the filling section of Paroda Canal at Ch. 4.600 Km.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond - Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.172/06/2023						151.11		No. WRD/ SD I/WD II/ F. /Camp/24-25. DATED: 03-06-2024.
	F.172/07/2023	27-05-2024	3/6/2024	Foundation	1.2.4	140 kg/cm2	137.78	145.19	
	F.172/08/2023						146.67		
2	F.172/09/2023						151.11		do
	F.172/10/2023	28-05-2024	4/6/2024	Foundation	1.2.4	140 kg/cm2	142.22	148.15	
	F.172/11/2023						151.11		
3	F.172/12/2023						146.67		do
	F.172/13/2023	29-05-2024	5/6/2024	Foundation	1.2.4	140 kg/cm2	137.78	146.67	
	F.172/14/2023						155.56		
4	F.172/15/2023						151.11		do
	F.172/16/2023	30-05-2024	6/6/2024	Foundation	1.2.4	140 kg/cm2	142.22	145.18	
	F.172/17/2023						142.22		
5	F.172/18/2023						151.11		do
	F.172/19/2023	31-05-2024	7/6/2024	Foundation	1.2.4	140 kg/cm2	142.22	146.67	
	F.172/20/2023						146.67		
6	F.172/21/2023						146.67		do
	F.172/22/2023	1/6/2024	10/6/2024	Foundation	1.2.4	140 kg/cm2	146.67	148.15	
	F.172/23/2023						151.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

NO.WRD/WDXI/SDIII/TECH/W.F.172/2023/2024-25/111

. Dated:-19/06/24

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Urgent Construction of retaining wall to retain the filling section of Paroda Canal at Ch. 4.600 Km.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond - Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
7	F.172/42/2023						146.67		No. WRD/ SD I/WD II/ F. /Camp/24-25. DATED: 10-06-2024.
	F.172/43/2023	3/6/2024	10/6/2024	Wall	1.2.4	140 kg/cm2	160.00	149.63	
	F.172/44/2023						142.22		
8	F.172/45/2023						155.56		do
	F.172/46/2023	4/6/2024	11/6/2024	Wall	1.2.4	140 kg/cm2	137.78	148.15	
	F.172/47/2023						151.11		
9	F.172/48/2023						155.56		do
	F.172/49/2023	5/6/2024	12/6/2024	Wall	1.2.4	140 kg/cm2	142.22	151.11	
	F.172/50/2023						155.56		
10	F.172/51/2023						155.56		do
	F.172/52/2023	6/6/2024	13-06-2024	Wall	1.2.4	140 kg/cm2	155.56	149.63	
	F.172/53/2023						137.78		
11	F.172/54/2023						151.11		do
	F.172/55/2023	7/6/2024	14-06-2024	Wall	1.2.4	140 kg/cm2	146.67	148.15	
	F.172/56/2023						146.67		
12	F.172/57/2023						155.56		do
	F.172/58/2023	8/6/2024	15-06-2024	Wall	1.2.4	140 kg/cm2	151.11	152.59	
	F.172/59/2023						151.11		
13	F.172/60/2023						155.56		do
	F.172/61/2023	9/6/2024	18-06-2024	Wall	1.2.4	140 kg/cm2	146.67	151.11	
	F.172/62/2023						151.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

NO.WRD/WDXI/SDIII/TECH/W.F.172/2023/2024-25/113

. Dated:-8/7/24

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Urgent Construction of retaining wall to retain the filling section of Paroda Canal at Ch. 4.600 Km.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond - Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
14	F.172/84/2023						142.22		No. WRD/ SD I/WD II/
	F.172/85/2023	10/6/2024	18-06-2024	Wall	1.2.4	140 kg/cm2	160.00	148.15	F. /Camp/24-25.
	F.172/86/2023						142.22		DATED: 14-06-2024.
15	F.172/87/2023						151.11		
	F.172/88/2023	11/6/2024	18-06-2024	Wall	1.2.4	140 kg/cm2	137.78	146.67	do
	F.172/89/2023						151.11		
16	F.172/90/2023						151.11		
	F.172/91/2023	12/6/2024	19-06-2024	Wall	1.2.4	140 kg/cm2	142.22	149.63	do
	F.172/92/2023						155.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER