

NO.WRD/WDXI/SDIII/TECH/W.F.69/2023/2023-24/10

. Dated:-03/04/24

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization to the right bank of nallah at Deulwada in Village Betoda of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.69/20/2023						235.56		No. WRD/WD XI/ SD IV/ W.F 598/708/2023-24. DATED: 08-03-2024.
	F.69/21/2023	22-02-2024	21-03-2024	Foundation	1.2.4	210 kg/cm2	226.67	228.15	
	F.69/22/2023						222.22		
1.2	F.69/23/2023						226.67		do
	F.69/24/2023	22-02-2024	21-03-2024	Foundation	1.2.4	210 kg/cm2	231.11	225.19	
	F.69/25/2023						217.78		
1.3	F.69/26/2023						231.11		do
	F.69/27/2023	22-02-2024	21-03-2024	Foundation	1.2.4	210 kg/cm2	208.89	222.22	
	F.69/28/2023						226.67		
1.4	F.69/29/2023						226.67		do
	F.69/30/2023	22-02-2024	21-03-2024	Foundation	1.2.4	210 kg/cm2	235.56	231.11	
	F.69/31/2023						231.11		
1.5	F.69/32/2023						217.78		do
	F.69/33/2023	22-02-2024	21-03-2024	Foundation	1.2.4	210 kg/cm2	240.00	228.15	
	F.69/34/2023						226.67		
1.6	F.69/35/2023						231.11		do
	F.69/36/2023	22-02-2024	21-03-2024	Foundation	1.2.4	210 kg/cm2	226.67	223.70	
	F.69/37/2023						213.33		
1.7	F.69/38/2023						226.67		do
	F.69/39/2023	22-02-2024	21-03-2024	Foundation	1.2.4	210 kg/cm2	231.11	228.15	
	F.69/40/2023						226.67		
1.8	F.69/41/2023						235.56		do
	F.69/42/2023	22-02-2024	21-03-2024	Foundation	1.2.4	210 kg/cm2	226.67	229.63	
	F.69/43/2023						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization to the right bank of nallah at Deulwada in Village Betoda of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
2.1	F.69/44/2023						222.22		No. WRD/WD XI/ SD IV/
	F.69/45/2023	24-02-2024	23-03-2024	1st Lift	1.2.4	210 kg/cm2	226.67	226.67	W.F 598/ 708 /2023-24.
	F.69/46/2023						231.11		DATED: 08-03-2024.
2.2	F.69/47/2023						226.67		
	F.69/48/2023	24-02-2024	23-03-2024	1st Lift	1.2.4	210 kg/cm2	235.56	231.11	do
	F.69/49/2023						231.11		
2.3	F.69/50/2023						240.00		
	F.69/51/2023	24-02-2024	23-03-2024	1st Lift	1.2.4	210 kg/cm2	226.67	226.67	do
	F.69/52/2023						213.33		
2.4	F.69/53/2023						217.78		
	F.69/54/2023	24-02-2024	23-03-2024	1st Lift	1.2.4	210 kg/cm2	244.44	231.11	do
	F.69/55/2023						231.11		
2.5	F.69/56/2023						222.22		
	F.69/57/2023	24-02-2024	23-03-2024	1st Lift	1.2.4	210 kg/cm2	231.11	229.63	do
	F.69/58/2023						235.56		
2.6	F.69/59/2023						235.56		
	F.69/60/2023	24-02-2024	23-03-2024	1st Lift	1.2.4	210 kg/cm2	213.33	228.15	do
	F.69/61/2023						235.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization to the right bank of nallah at Deulwada in Village Betoda of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.1	F.69/62/2023						226.67		No. WRD/WD XI/ SD IV/
	F.69/63/2023	26-02-2024	26-03-2024	2nd Lift	1.2.4	210 kg/cm2	222.22	225.19	W.F 598/ 708 /2023-24.
	F.69/64/2023						226.67		DATED: 08-03-2024.
3.2	F.69/65/2023						231.11		
	F.69/66/2023	26-02-2024	26-03-2024	2nd Lift	1.2.4	210 kg/cm2	226.67	226.67	do
	F.69/67/2023						222.22		
3.3	F.69/68/2023						235.56		
	F.69/69/2023	26-02-2024	26-03-2024	2nd Lift	1.2.4	210 kg/cm2	217.78	228.15	do
	F.69/70/2023						231.11		
3.4	F.69/71/2023						231.11		
	F.69/72/2023	26-02-2024	26-03-2024	2nd Lift	1.2.4	210 kg/cm2	226.67	225.19	do
	F.69/73/2023						217.78		
4.1	F.69/74/2023						231.11		
	F.69/75/2023	28-02-2024	27-03-2024	3rd Lift	1.2.4	210 kg/cm2	235.56	231.11	do
	F.69/76/2023						226.67		
4.2	F.69/77/2023						231.11		
	F.69/78/2023	28-02-2024	27-03-2024	3rd Lift	1.2.4	210 kg/cm2	226.67	229.63	do
	F.69/79/2023						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization to the right bank of nallah at Deulwada in Village Betoda of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.69/80/2023						231.11		No. WRD/WD XI/ SD IV/
	F.69/81/2023	29-02-2024	28-03-2024	Side wall	1.2.4	210 kg/cm2	222.22	223.70	W.F 598/ 708 /2023-24.
	F.69/82/2023						217.78		DATED: 08-03-2024.
5.2	F.69/83/2023						226.60		
	F.69/84/2023	29-02-2024	28-03-2024	Side wall	1.2.4	210 kg/cm2	231.11	226.64	do
	F.69/85/2023						222.22		
6	F.69/86/2023						235.56		
	F.69/87/2023	2/3/2024	30-03-2024	Side wall	1.2.4	210 kg/cm2	226.67	229.63	do
	F.69/88/2023						226.67		
7	F.69/89/2023						231.11		
	F.69/90/2023	4/3/2024	1/4/2024	Platform	1.2.4	210 kg/cm2	222.22	229.63	do
	F.69/91/2023						235.56		
8	F.69/92/2023						226.67		
	F.69/93/2023	6/3/2024	3/4/2024	Platform	1.2.4	210 kg/cm2	231.11	228.15	do
	F.69/94/2023						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER