

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Urgent Construction of retaining wall to retain the filling section of Paroda Canal at Ch. 4.700 Km.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond - Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.176/06/2023						151.11		No. WRD/ SD I/WD II/ F. /Camp/24-25. DATED: 06-06-2024.
	F.176/07/2023	30-05-2024	6/6/2024	Foundation	1.2.4	140 kg/cm2	142.22	146.67	
	F.176/08/2023						146.67		
2	F.176/09/2023						151.11		do
	F.176/10/2023	31-05-2024	7/6/2024	Foundation	1.2.4	140 kg/cm2	142.22	149.63	
	F.176/11/2023						155.56		
3	F.176/12/2023						146.67		do
	F.176/13/2023	1/6/2024	10/6/2024	Foundation	1.2.4	140 kg/cm2	142.22	148.15	
	F.176/14/2023						155.56		
4	F.176/15/2023						151.11		do
	F.176/16/2023	2/6/2024	10/6/2024	Foundation	1.2.4	140 kg/cm2	142.22	145.18	
	F.176/17/2023						142.22		
5	F.176/18/2023						151.11		do
	F.176/19/2023	3/6/2024	10/6/2024	Foundation	1.2.4	140 kg/cm2	146.67	148.15	
	F.176/20/2023						146.67		
6	F.176/21/2023						155.56		do
	F.176/22/2023	4/6/2024	11/6/2024	Foundation	1.2.4	140 kg/cm2	146.67	151.11	
	F.176/23/2023						151.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Urgent Construction of retaining wall to retain the filling section of Paroda Canal at Ch. 4.700 Km.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond - Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
7	F.176/42/2023						151.11		No. WRD/ SD I/WD II/ F. /Camp/2024-25. DATED: 13-06-2024.
	F.176/43/2023	6/6/2024	13-06-2024	Wall	1.2.4	140 kg/cm2	142.22	146.67	
	F.176/44/2023						146.67		
8	F.176/45/2023						155.56		do
	F.176/46/2023	7/6/2024	14-06-2024	Wall	1.2.4	140 kg/cm2	142.22	149.63	
	F.176/47/2023						151.11		
9	F.176/48/2023						146.67		do
	F.176/49/2023	8/6/2024	15-06-2024	Wall	1.2.4	140 kg/cm2	137.78	148.15	
	F.176/50/2023						160.00		
10	F.176/51/2023						151.11		do
	F.176/52/2023	9/6/2024	18-06-2024	Wall	1.2.4	140 kg/cm2	151.11	148.15	
	F.176/53/2023						142.22		
11	F.176/54/2023						155.56		do
	F.176/55/2023	10/6/2024	18-06-2024	Wall	1.2.4	140 kg/cm2	137.78	146.67	
	F.176/56/2023						146.67		
12	F.176/57/2023						155.56		do
	F.176/58/2023	11/6/2024	18-06-2024	Wall	1.2.4	140 kg/cm2	146.67	148.15	
	F.176/59/2023						142.22		
13	F.176/60/2023						151.11		do
	F.176/61/2023	12/6/2024	19-06-2024	Wall	1.2.4	140 kg/cm2	137.78	145.19	
	F.176/62/2023						146.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

NO.WRD/WDXI/SDIII/TECH/W.F.176/2023/2024-25/118

. Dated:-24/06/24

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Urgent Construction of retaining wall to retain the filling section of Paroda Canal at Ch. 4.700 Km.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfod - Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
14	F.176/84/2023						155.56		No. WRD/ SD I/WD II/
	F.176/85/2023	13-06-2024	20-06-2024	Wall	1.2.4	140 kg/cm2	142.22	148.15	F. / Camp /2024-25.
	F.176/86/2023						146.67		DATED: 17-06-2024.
15	F.176/87/2023						146.67		
	F.176/88/2023	14-06-2024	21-06-2024	Wall	1.2.4	140 kg/cm2	142.22	146.67	do
	F.176/89/2023						151.11		
16	F.176/90/2023						146.67		
	F.176/91/2023	15-06-2024	22-06-2024	Wall	1.2.4	140 kg/cm2	142.22	149.63	do
	F.176/92/2023						160.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER