

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of flood protection wall in Sy.No. 8/5, 6 & 7 Village Collem in Dharbandora Taluka of Sanvordem Constituency.

**SAMPLE SENT BY:** AE, SD III, WD XII, WRD, Dharbandora- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.20/05/2022						231.11		No. WRD/WD XII/ SD III/ W.F.01/182/2022-23. <b>DATED: 05-01-2023.</b>
	F.20/06/2022	13-12-2022	10/1/2023	Foundation LHS Retaining Wall	1.2.4	210 kg/cm2	226.67	229.63	
	F.20/07/2022						231.11		
1.2	F.20/08/2022						226.67		
	F.20/09/2022	13-12-2022	10/1/2023	Foundation LHS Retaining Wall	1.2.4	210 kg/cm2	235.56	231.11	do
	F.20/10/2022						231.11		
2.1	F.20/11/2022						222.22		
	F.20/12/2022	20-12-2022	17-01-2023	1st lift LHS Wing Retaining wall	1.2.4	210 kg/cm2	213.33	220.74	do
	F.20/13/2022						226.67		
2.2	F.20/14/2022						222.22		
	F.20/09/2022	20-12-2022	17-01-2023	1st lift LHS Wing Retaining wall	1.2.4	210 kg/cm2	226.67	222.22	do
	F.20/10/2022						217.78		
3.1	F.20/11/2022						235.56		
	F.20/12/2022	23-12-2022	20-01-2023	Foundation LHS Retaining Wall	1.2.4	210 kg/cm2	240.00	235.56	do
	F.20/13/2022						231.11		
3.2	F.20/14/2022						231.11		
	F.20/15/2022	23-12-2022	20-01-2023	Foundation LHS Retaining Wall	1.2.4	210 kg/cm2	235.56	231.11	do
	F.20/16/2022						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

## SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Construction of flood protection wall in Sy.No. 8/5, 6 & 7 Village Collem in Dharbandora Taluka of Sanvordem Constituency.

**SAMPLE SENT BY:** AE, SD III, WD XII, WRD, Dharbandora- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.1	F.20/17/2022						231.11		No. WRD/WD XII/ SD III/ W.F.01/182/2022-23. <b>DATED: 05-01-2023.</b>
	F.20/18/2022	29-12-2022	27-01-2023	II nd lift LHS Retaining wall	1.2.4	210 kg/cm2	226.67	223.70	
	F.20/19/2022						213.33		
4.2	F.20/20/2022						226.67		
	F.20/21/2022	29-12-2022	27-01-2023	II nd lift LHS Retaining wall	1.2.4	210 kg/cm2	222.22	222.22	do
	F.20/22/2022						217.78		
5.1	F.20/23/2022						226.67		
	F.20/24/2022	3/1/2023	31-01-2023	Ist lift LHS Retaining wall	1.2.4	210 kg/cm2	208.89	220.74	do
	F.20/25/2022						226.67		
5.2	F.20/26/2022						222.22		
	F.20/27/2022	3/1/2023	31-01-2023	Ist lift LHS Retaining wall	1.2.4	210 kg/cm2	226.67	225.19	do
	F.20/28/2022						226.67		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**