

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of existing nullah adjacent to Sy.No. 9/0 of Village at Chamramaddem, Voddy in Cuncolim Constituency.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.152/06/2023						231.11		No. 344/ SD III/ WD III/ WRD/24-25/65 DATED: 28-05-2024
	F.152/07/2023	14-05-2024	11/6/2024	Bed PCC	1.2.4	210 kg/cm2	235.56	232.59	
	F.152/08/2023						231.11		
1.2	F.152/09/2023						240.00		
	F.152/10/2023	14-05-2024	11/6/2024	Bed PCC	1.2.4	210 kg/cm2	226.67	234.08	do
	F.152/11/2023						235.56		
2.1	F.152/12/2023						226.67		
	F.152/13/2023	15-05-2024	12/6/2024	LHS & RHS wall	1.2.4	210 kg/cm2	217.78	225.19	do
	F.152/14/2023						231.11		
2.2	F.152/15/2023						222.22		
	F.152/16/2023	15-05-2024	12/6/2024	LHS & RHS wall	1.2.4	210 kg/cm2	226.67	226.67	do
	F.152/17/2023						231.11		
3.1	F.152/18/2023						226.67		
	F.152/19/2023	16-05-2024	13-06-2024	Bed PCC	1.2.4	210 kg/cm2	231.11	228.15	do
	F.152/20/2023						226.67		
3.2	F.152/21/2023						231.11		
	F.152/22/2023	16-05-2024	13-06-2024	Bed PCC	1.2.4	210 kg/cm2	235.56	229.63	do
	F.152/23/2023						222.22		
4.1	F.152/24/2023						231.11		
	F.152/25/2023	17-05-2024	14-06-2024	Bed PCC	1.2.4	210 kg/cm2	231.11	228.15	do
	F.152/26/2023						222.22		
4.2	F.152/27/2023						235.56		
	F.152/28/2023	17-05-2024	14-06-2024	Bed PCC	1.2.4	210 kg/cm2	217.78	231.11	do
	F.152/29/2023						240.00		

JUNIOR ENGINEER.

GOVERNMENT OF GOA

ASSISTANT ENGINEER

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of existing nullah adjacent to Sy.No. 9/0 of Village at Chamramaddem, Voddy in Cuncolim Constituency.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
5.1	F.152/30/2023						222.22		No. 344/ SD III/ WD III/ WRD/24-25/65 DATED: 28-05-2024
	F.152/31/2023	18-05-2024	15-06-2024	Bed PCC	1.2.4	210 kg/cm ²	235.56	228.15	
	F.152/32/2023						226.67		
5.2	F.152/33/2023						226.67		
	F.152/34/2023	18-05-2024	15-06-2024	Bed PCC	1.2.4	210 kg/cm ²	231.11	228.15	do
	F.152/35/2023						226.67		
6.1	F.152/36/2023						213.33		
	F.152/37/2023	20-05-2024	18-06-2024	LHS & RHS wall	1.2.4	210 kg/cm ²	235.56	226.67	do
	F.152/38/2023						231.11		
6.2	F.152/39/2023						226.67		
	F.152/40/2023	20-05-2024	18-06-2024	LHS & RHS wall	1.2.4	210 kg/cm ²	231.11	228.15	do
	F.152/41/2023						226.67		
6.3	F.152/42/2023						235.56		
	F.152/43/2023	20-05-2024	18-06-2024	LHS & RHS wall	1.2.4	210 kg/cm ²	222.22	228.15	do
	F.152/44/2023						226.67		
7.1	F.152/45/2023						226.67		
	F.152/46/2023	22-05-2024	19-06-2024	Bed PCC	1.2.4	210 kg/cm ²	231.11	229.63	do
	F.152/47/2023						231.11		
7.2	F.152/48/2023						235.56		
	F.152/49/2023	22-05-2024	19-06-2024	Bed PCC	1.2.4	210 kg/cm ²	217.78	226.67	do
	F.152/50/2023						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of existing nullah adjacent to Sy.No. 9/0 of Village at Chamramaddem, Voddy in Cuncolim Constituency.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
8.1	F.152/51/2023						226.67		No. 344/ SD III/ WD III/ WRD/24-25/65 DATED: 28-05-2024
	F.152/52/2023	25-05-2024	22-06-2024	LHS & RHS Wall	1.2.4	210 kg/cm2	231.11	228.15	
	F.152/53/2023						226.67		
8.2	F.152/54/2023						240.00		
	F.152/55/2023	25-05-2024	22-06-2024	LHS & RHS Wall	1.2.4	210 kg/cm2	204.44	225.18	do
	F.152/56/2023						231.11		
8.3	F.152/57/2023						226.67		
	F.152/58/2023	25-05-2024	22-06-2024	LHS & RHS Wall	1.2.4	210 kg/cm2	231.11	229.63	do
	F.152/59/2023						231.11		
9.1	F.152/60/2023						226.67		
	F.152/61/2023	27-05-2024	24-06-2024	LHS & RHS wall	1.2.4	210 kg/cm2	231.11	231.11	do
	F.152/62/2023						235.56		
9.2	F.152/63/2023						235.56		
	F.152/64/2023	27-05-2024	24-06-2024	LHS & RHS wall	1.2.4	210 kg/cm2	226.67	228.15	do
	F.152/65/2023						222.22		
9.3	F.152/66/2023						226.67		
	F.152/67/2023	27-05-2024	24-06-2024	LHS & RHS wall	1.2.4	210 kg/cm2	226.67	229.63	do
	F.152/68/2023						235.56		
9.4	F.152/69/2023						213.33		
	F.152/70/2023	27-05-2024	24-06-2024	LHS & RHS wall	1.2.4	210 kg/cm2	231.11	226.67	do
	F.152/71/2023						235.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER