

NO.WRD/WDXI/SDIII/TECH/W.F.172/2023/2024-25/121

. Dated:-02/7/24

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Urgent Construction of retaining wall to retain the filling section of Paroda Canal at Ch. 4.600 Km.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond - Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.172/24/2023						235.56		No. WRD/ SD I/WD II/ F. /Camp/24-25. DATED: 03-06-2024.
	F.172/25/2023	27-05-2024	24-06-2024	Foundation	1.2.4	210 kg/cm2	226.67	229.63	
	F.172/26/2023						226.67		
2	F.172/27/2023						231.11		do
	F.172/28/2023	28-05-2024	25-06-2024	Foundation	1.2.4	210 kg/cm2	231.11	228.15	
	F.172/29/2023						222.22		
3	F.172/30/2023						235.56		do
	F.172/31/2023	29-05-2024	26-06-2024	Foundation	1.2.4	210 kg/cm2	231.11	229.63	
	F.172/32/2023						222.22		
4	F.172/33/2023						235.56		do
	F.172/34/2023	30-05-2024	27-06-2024	Foundation	1.2.4	210 kg/cm2	235.56	231.11	
	F.172/35/2023						222.22		
5	F.172/36/2023						231.11		do
	F.172/37/2023	31-05-2024	28-06-2024	Foundation	1.2.4	210 kg/cm2	231.11	229.63	
	F.172/38/2023						226.67		
6	F.172/39/2023						235.56		do
	F.172/40/2023	1/6/2024	29-06-2024	Foundation	1.2.4	210 kg/cm2	231.11	228.15	
	F.172/41/2023						217.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

NO.WRD/WDXI/SDIII/TECH/W.F.172/2023/2024-25/132

. Dated:-8/7/24

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Urgent Construction of retaining wall to retain the filling section of Paroda Canal at Ch. 4.600 Km.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond - Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
7	F.172/63/2023						235.56		No. WRD/ SD I/WD II/ F. /Camp/24-25. DATED: 10-06-2024.
	F.172/64/2023	3/6/2024	1/7/2024	Wall	1.2.4	210 kg/cm2	226.67	226.67	
	F.172/65/2023						217.78		
8	F.172/66/2023						226.67		do
	F.172/67/2023	4/6/2024	2/7/2024	Wall	1.2.4	210 kg/cm2	231.11	225.19	
	F.172/68/2023						217.78		
9	F.172/69/2023						231.11		do
	F.172/70/2023	5/6/2024	3/7/2024	Wall	1.2.4	210 kg/cm2	213.33	223.70	
	F.172/71/2023						226.67		
10	F.172/72/2023						213.33		do
	F.172/73/2023	6/6/2024	4/7/2024	Wall	1.2.4	210 kg/cm2	235.56	226.67	
	F.172/74/2023						231.11		
11	F.172/75/2023						222.22		do
	F.172/76/2023	7/6/2024	5/7/2024	Wall	1.2.4	210 kg/cm2	231.11	226.67	
	F.172/77/2023						226.67		
12	F.172/78/2023						231.11		do
	F.172/79/2023	8/6/2024	6/7/2024	Wall	1.2.4	210 kg/cm2	226.67	225.19	
	F.172/80/2023						217.78		
13	F.172/81/2023						226.67		do
	F.172/82/2023	9/6/2024	8/7/2024	Wall	1.2.4	210 kg/cm2	231.11	228.15	
	F.172/83/2023						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

NO.WRD/WDXI/SDIII/TECH/W.F.172/2023/2024-25/ 134

. Dated:-10/7/24

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Urgent Construction of retaining wall to retain the filling section of Paroda Canal at Ch. 4.600 Km.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond - Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
14	F.172/93/2023						226.67		No. WRD/ SD I/WD II/
	F.172/94/2023	10/6/2024	8/7/2024	Wall	1.2.4	210 kg/cm ²	222.22	225.19	F. / Camp /24-25.
	F.172/95/2023						226.67		DATED: 14-06-2024.
15	F.172/96/2023						231.11		
	F.172/97/2023	11/6/2024	9/7/2024	Wall	1.2.4	210 kg/cm ²	226.67	226.67	do
	F.172/98/2023						222.22		
16	F.172/99/2023						235.56		
	F.172/100/2023	12/6/2024	10/7/2024	Wall	1.2.4	210 kg/cm ²	217.78	228.15	do
	F.172/101/2023						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER