

NO.WRD/WDXI/SDIII/TECH/W.F.176/2023/2024-25/122

. Dated:-02/07/24

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Urgent Construction of retaining wall to retain the filling section of Paroda Canal at Ch. 4.700 Km.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond - Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

| REPORT NO | SAMPLE NOS. | CASTING DATE | TESTING DATE | LOCATION OF SAMPLE | MIX PROPORTION | TARGET STRENGTH | Comp sth in Kg/cm2 | Avg. Comp Kg/cm2 | LETTER No / DATED |
|-----------|---------------|--------------|--------------|--------------------|----------------|-----------------|--------------------|------------------|--|
| 1 | F.176/24/2023 | | | | | | 235.56 | | No. WRD/ SD I/WD II/ F. /Camp/24-25. DATED: 06-06-2024. |
| | F.176/25/2023 | 30-05-2024 | 27-06-2024 | Foundation | 1.2.4 | 210 kg/cm2 | 222.22 | 228.15 | |
| | F.176/26/2023 | | | | | | 226.67 | | |
| 2 | F.176/27/2023 | | | | | | 231.11 | | do |
| | F.176/28/2023 | 31-05-2024 | 28-06-2024 | Foundation | 1.2.4 | 210 kg/cm2 | 235.56 | 229.63 | |
| | F.176/29/2023 | | | | | | 222.22 | | |
| 3 | F.176/30/2023 | | | | | | 235.56 | | do |
| | F.176/31/2023 | 1/6/2024 | 29-06-2024 | Foundation | 1.2.4 | 210 kg/cm2 | 231.11 | 231.11 | |
| | F.176/32/2023 | | | | | | 226.67 | | |
| 4 | F.176/33/2023 | | | | | | 231.11 | | do |
| | F.176/34/2023 | 2/6/2024 | 30-06-2024 | Foundation | 1.2.4 | 210 kg/cm2 | 231.11 | 228.15 | |
| | F.176/35/2023 | | | | | | 222.22 | | |
| 5 | F.176/36/2023 | | | | | | 235.56 | | do |
| | F.176/37/2023 | 3/6/2024 | 1/7/2024 | Foundation | 1.2.4 | 210 kg/cm2 | 235.56 | 229.63 | |
| | F.176/38/2023 | | | | | | 217.78 | | |
| 6 | F.176/39/2023 | | | | | | 235.56 | | do |
| | F.176/40/2023 | 4/6/2024 | 2/7/2024 | Foundation | 1.2.4 | 210 kg/cm2 | 231.11 | 226.67 | |
| | F.176/41/2023 | | | | | | 213.33 | | |

JUNIOR ENGINEER.

ASSISTANT ENGINEER

NO.WRD/WDXI/SDIII/TECH/W.F.176/2023/2024-25/133

. Dated:-10/07/24

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Urgent Construction of retaining wall to retain the filling section of Paroda Canal at Ch. 4.700 Km.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond - Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

| REPORT NO | SAMPLE NOS. | CASTING DATE | TESTING DATE | LOCATION OF SAMPLE | MIX PROPORTION | TARGET STRENGTH | Comp sth in Kg/cm2 | Avg. Comp Kg/cm2 | LETTER No / DATED |
|-----------|---------------|--------------|--------------|--------------------|----------------|-----------------|--------------------|------------------|--|
| 7 | F.176/63/2023 | | | | | | 235.56 | | No. WRD/ SD I/WD II/ F. /Camp/2024-25. DATED: 13-06-2024. |
| | F.176/64/2023 | 6/6/2024 | 4/7/2024 | Wall | 1.2.4 | 210 kg/cm2 | 222.22 | 225.19 | |
| | F.176/65/2023 | | | | | | 217.78 | | |
| 8 | F.176/66/2023 | | | | | | 226.67 | | do |
| | F.176/67/2023 | 7/6/2024 | 5/7/2024 | Wall | 1.2.4 | 210 kg/cm2 | 231.11 | 226.67 | |
| | F.176/68/2023 | | | | | | 222.22 | | |
| 9 | F.176/69/2023 | | | | | | 235.56 | | do |
| | F.176/70/2023 | 8/6/2024 | 6/7/2024 | Wall | 1.2.4 | 210 kg/cm2 | 226.67 | 229.63 | |
| | F.176/71/2023 | | | | | | 226.67 | | |
| 10 | F.176/72/2023 | | | | | | 231.11 | | do |
| | F.176/73/2023 | 9/6/2024 | 8/7/2024 | Wall | 1.2.4 | 210 kg/cm2 | 213.33 | 226.67 | |
| | F.176/74/2023 | | | | | | 235.56 | | |
| 11 | F.176/75/2023 | | | | | | 226.67 | | do |
| | F.176/76/2023 | 10/6/2024 | 8/7/2024 | Wall | 1.2.4 | 210 kg/cm2 | 231.11 | 228.15 | |
| | F.176/77/2023 | | | | | | 226.67 | | |
| 12 | F.176/78/2023 | | | | | | 231.11 | | do |
| | F.176/79/2023 | 11/6/2024 | 9/7/2024 | Wall | 1.2.4 | 210 kg/cm2 | 226.67 | 225.19 | |
| | F.176/80/2023 | | | | | | 217.78 | | |
| 13 | F.176/81/2023 | | | | | | 235.56 | | do |
| | F.176/82/2023 | 12/6/2024 | 10/7/2024 | Wall | 1.2.4 | 210 kg/cm2 | 222.22 | 226.67 | |
| | F.176/83/2023 | | | | | | 222.22 | | |

JUNIOR ENGINEER.

ASSISTANT ENGINEER

NO.WRD/WDXI/SDIII/TECH/W.F.176/2023/2024-25/137

. Dated:-18/7/24

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Urgent Construction of retaining wall to retain the filling section of Paroda Canal at Ch. 4.700 Km.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond - Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

| REPORT NO | SAMPLE NOS. | CASTING DATE | TESTING DATE | LOCATION OF SAMPLE | MIX PROPORTION | TARGET STRENGTH | Comp sth in Kg/cm ² | Avg. Comp Kg/cm ² | LETTER No / DATED |
|-----------|----------------|--------------|--------------|--------------------|----------------|------------------------|--------------------------------|------------------------------|----------------------------|
| 14 | F.176/93/2023 | | | | | | 226.67 | | No. WRD/ SD I/WD II/ |
| | F.176/94/2023 | 13-06-2024 | 11/7/2024 | Wall | 1.2.4 | 210 kg/cm ² | 222.22 | 225.19 | F. / Camp /2024-25. |
| | F.176/95/2023 | | | | | | 226.67 | | DATED: 17-06-2024. |
| 15 | F.176/96/2023 | | | | | | 231.11 | | |
| | F.176/97/2023 | 14-06-2024 | 12/7/2024 | Wall | 1.2.4 | 210 kg/cm ² | 226.67 | 226.67 | do |
| | F.176/98/2023 | | | | | | 222.22 | | |
| 16 | F.176/99/2023 | | | | | | 235.56 | | |
| | F.176/100/2023 | 15-06-2024 | 15-07-2024 | Wall | 1.2.4 | 210 kg/cm ² | 217.78 | 228.15 | do |
| | F.176/101/2023 | | | | | | 231.11 | | |

JUNIOR ENGINEER.

ASSISTANT ENGINEER