

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to various nallah at Gaumwaddo (A) from Fr.Agnelo's house (B) approaching from hillside/ mainroad at Mr. Franco Mascarenhas (C) near Mr.Shaba Parab house and others at V.P. Anjuna in Siolim Constituency.

SAMPLE SENT BY: AE, SD II, WD I, WRD, Mapusa, Bardez- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1	F.146/05/2023						235.56		No. SD II/ WD I/WRD/ F.24/24-25/36. DATED:23-04-2024
	F.146/06/2023	15-04-2024	13-05-2024	Foundation	1.2.4	210 kg/cm ²	226.67	228.15	
	F.146/07/2023						222.22		
2	F.146/08/2023						226.67		do
	F.146/09/2023	16-04-2024	14-05-2024	Foundation	1.2.4	210 kg/cm ²	231.11	225.19	
	F.146/10/2023						217.78		
3	F.146/11/2023						231.11		do
	F.146/12/2023	18-04-2024	16-05-2024	Foundation	1.2.4	210 kg/cm ²	208.89	222.22	
	F.146/13/2023						226.67		
4	F.146/14/2023						226.67		do
	F.146/15/2023	19-04-2024	17-05-2024	1st Lift	1.2.4	210 kg/cm ²	235.56	231.11	
	F.146/16/2023						231.11		
5	F.146/17/2023						217.78		do
	F.146/18/2023	20-04-2024	18-05-2024	1st Lift	1.2.4	210 kg/cm ²	240.00	228.15	
	F.146/19/2023						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to various nallah at Gaumwaddo (A) from Fr.Agnelo's house (B) approaching from hillside/ mainroad at Mr. Franco Mascarenhas (C) near Mr.Shaba Parab house and others at V.P. Anjuna in Siolim Constituency.

SAMPLE SENT BY: AE, SD II, WD I, WRD, Mapusa, Bardez- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
6	F.146/20/2023						222.22		No. SD II/ WD I/WRD/ F.24/24-25/99. DATED: 17-05-2024
	F.146/21/2023	25-04-2024	23-05-2024	Foundation	1.2.4	210 kg/cm2	226.67	226.67	
	F.146/22/2023						231.11		
7	F.146/23/2023						226.67		
	F.146/24/2023	26-04-2024	24-05-2024	Foundation	1.2.4	210 kg/cm2	235.56	231.11	do
	F.146/25/2023						231.11		
8	F.146/26/2023						240.00		
	F.146/27/2023	27-04-2024	25-05-2024	1st Lift	1.2.4	210 kg/cm2	226.67	226.67	do
	F.146/28/2023						213.33		
9	F.146/29/2023						217.78		
	F.146/30/2023	29-04-2024	27-05-2024	1st Lift	1.2.4	210 kg/cm2	244.44	231.11	do
	F.146/31/2023						231.11		
10	F.146/32/2023						222.22		
	F.146/33/2023	30-04-2024	28-05-2024	1st Lift	1.2.4	210 kg/cm2	231.11	229.63	do
	F.146/34/2023						235.56		
11	F.146/35/2023						235.56		
	F.146/36/2023	2/5/2024	30-05-2024	1st Lift	1.2.4	210 kg/cm2	213.33	228.15	do
	F.146/37/2023						235.56		
12	F.146/38/2023						235.56		
	F.146/39/2023	3/5/2024	31-05-2024	Foundation	1.2.4	210 kg/cm2	226.67	229.63	do
	F.146/40/2023						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to various nallah at Gaumwaddo (A) from Fr.Agnelo's house (B) approaching from hillside/ mainroad at Mr. Franco Mascarenhas (C) near Mr.Shaba Parab house and others at V.P. Anjuna in Siolim Constituency.

SAMPLE SENT BY: AE, SD II, WD I, WRD, Mapusa, Bardez- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
13	F.146/41/2023						226.67		No. SD II/ WD I/WRD/ F.24/24-25/99. DATED: 17-05-2024
	F.146/42/2023	4/5/2024	1/6/2024	Foundation	1.2.4	210 kg/cm2	235.56	229.63	
	F.146/43/2023						226.67		
14	F.146/44/2023						231.11		do
	F.146/45/2023	6/5/2024	3/6/2024	Foundation	1.2.4	210 kg/cm2	226.67	226.67	
	F.146/46/2023						222.22		
15	F.146/47/2023						235.56		do
	F.146/49/2023	7/5/2024	4/6/2024	1st Lift	1.2.4	210 kg/cm2	217.78	228.15	
	F.146/50/2023						231.11		
16	F.146/51/2023						231.11		do
	F.146/52/2023	8/5/2024	5/6/2024	1st Lift	1.2.4	210 kg/cm2	226.67	225.19	
	F.146/53/2023						217.78		
17	F.146/54/2023						231.11		do
	F.146/55/2023	9/5/2024	6/6/2024	2nd Lift	1.2.4	210 kg/cm2	235.56	229.63	
	F.146/56/2023						222.22		
18	F.146/57/2023						231.11		do
	F.146/58/2023	10/5/2024	7/6/2024	2nd Lift	1.2.4	210 kg/cm2	226.67	229.63	
	F.146/59/2023						231.11		
19	F.146/60/2023						235.56		do
	F.146/61/2023	11/5/2024	10/6/2024	Foundation	1.2.4	210 kg/cm2	231.11	228.15	
	F.146/62/2023						217.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to various nallah at Gaumwaddo (A) from Fr.Agnelo's house (B) approaching from hillside/ mainroad at Mr. Franco Mascarenhas (C) near Mr.Shaba Parab house and others at V.P. Anjuna in Siolim Constituency.

SAMPLE SENT BY: AE, SD II, WD I, WRD, Mapusa, Bardez- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
20	F.146/63/2023						235.56		No. SD II/ WD I/WRD/ F.24/24-25/99. DATED: 17-05-2024
	F.146/64/2023	13-05-2024	10/6/2024	Foundation	1.2.4	210 kg/cm2	222.22	225.19	
	F.146/65/2023						217.78		
21	F.146/66/2023						226.60		do
	F.146/67/2023	14-05-2024	11/6/2024	Foundation	1.2.4	210 kg/cm2	231.11	226.64	
	F.146/68/2023						222.22		
22	F.146/69/2023						235.56		do
	F.146/70/2023	15-05-2024	12/6/2024	1st Lift	1.2.4	210 kg/cm2	226.67	229.63	
	F.146/71/2023						226.67		
23	F.146/72/2023						231.11		do
	F.146/73/2023	16-05-2024	13-06-2024	1st Lift	1.2.4	210 kg/cm2	213.33	226.67	
	F.146/74/2023						235.56		
24	F.146/75/2023						226.67		do
	F.146/76/2023	17-05-2024	14-06-2024	1st Lift	1.2.4	210 kg/cm2	231.11	228.15	
	F.146/77/2023						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

NO.WRD/WDXI/SDIII/TECH/W.F.146-Oct-2023/2024-25/129

. Dated:-08/07/24

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to various nallah at Gaumwaddo (A) from Fr.Agnelo's house (B) approaching from hillside/ mainroad at Mr. Franco Mascarenhas (C) near Mr.Shaba Parab house and others at V.P. Anjuna in Siolim Constituency.

SAMPLE SENT BY: AE, SD II, WD I, WRD, Mapusa, Bardez- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
25	F.146/78/2023						235.56		No. SD II/ WD I/WRD/ F.24/24-25/158. DATED: 18-06-2024
	F.146/79/2023	22-05-2024	19-06-2024	Foundation	1.2.4	210 kg/cm2	226.67	228.15	
	F.146/80/2023						222.22		
26	F.146/81/2023						231.11		
	F.146/82/2023	25-05-2024	22-06-2024	Foundation	1.2.4	210 kg/cm2	226.67	226.67	do
	F.146/83/2023						222.22		
27	F.146/84/2023						231.11		
	F.146/85/2023	27-05-2024	24-06-2024	Foundation	1.2.4	210 kg/cm2	226.67	228.15	do
	F.146/86/2023						226.67		
28	F.146/87/2023						231.11		
	F.146/88/2023	29-05-2024	26-06-2024	1st Lift	1.2.4	210 kg/cm2	240.00	229.63	do
	F.146/89/2023						217.78		
29	F.146/90/2023						235.56		
	F.146/91/2023	1/6/2024	29-06-2024	1st Lift	1.2.4	210 kg/cm2	226.67	229.63	do
	F.146/92/2023						226.67		
30	F.146/93/2023						240.00		
	F.146/94/2023	3/6/2024	1/7/2024	2nd Lift	1.2.4	210 kg/cm2	217.78	228.15	do
	F.146/95/2023						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to various nallah at Gaumwaddo (A) from Fr.Agnelo's house (B) approaching from hillside/ mainroad at Mr. Franco Mascarenhas (C)

near Mr.Shaba Parab house and others at V.P. Anjuna in Siolim Constituency.

SAMPLE SENT BY: AE, SD II, WD I, WRD, Mapusa, Bardez- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
31	F.146/96/2023						235.56		No. SD II/ WD I/WRD/ F.24/24-25/158. DATED: 18-06-2024
	F.146/97/2023	4/6/2024	2/7/2024	2nd Lift	1.2.4	210 kg/cm2	222.22	223.70	
	F.146/98/2023						213.33		
32	F.146/99/2023						235.56		do
	F.146/100/2023	5/6/2024	3/7/2024	Foundation	1.2.4	210 kg/cm2	222.22	226.67	
	F.146/101/2023						222.22		
33	F.146/102/2023						231.11		do
	F.146/103/2023	6/6/2024	4/7/2024	1st Lift	1.2.4	210 kg/cm2	226.67	225.19	
	F.146/104/2023						217.78		
34	F.146/105/2023						231.11		do
	F.146/106/2023	7/6/2024	5/7/2024	1st Lift	1.2.4	210 kg/cm2	226.67	226.67	
	F.146/107/2023						222.22		
35	F.146/108/2023						235.56		do
	F.146/109/2023	8/6/2024	6/7/2024	2nd Lift	1.2.4	210 kg/cm2	231.11	228.15	
	F.146/110/2023						217.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER