

GOVERNMENT OF GOA
WATER RESOURCES DEPARTMENT
S.D.III., Works Div. XI, QUALITY CONTROL LABORATORY
Gogol - Margao - Goa.

No. WRD / WD XI / SDIII / TECH / WF.43-Oct-2022 /129/2022-23.

Dated:10/02/2023

Name of the Work: Providing R.C.C canal lining to minor M1 canal between Ch.1.500 km to 2.400 km in Cacora Village of Quepem Taluka.

Sample Sent by: Assistant Engineer , SD I , WD X , WRD , Quepem- Goa.

Letter No: WRD/WD X/SD I/W.F.1/208/2022-23.

Dated:- 08-02-2023.

Received on: 9/2/2023

Date of Testing 10/2/2023

REPORT

Sample No.	Type of Sample	Tested for	Result	Permissible value	REMARKS
F.43/01/2022	Coarse Sand	FM Silt & Clay Grading	2.331 3.20% Zone III	2.3 to 3.1 Upto 5% Zone I to III	
F.43/02/2022	Aggregate-20 mm	Grading		As per IS-383:2016	To get the20mm graded aggregate nominal size blend 20mm & 10 mm metal in 1:1 proportion.
F.43/03/2022	Aggregate- 10 mm	Grading		As per IS-383:2016	

Junior Engineer

Assistant Engineer

- Copy submitted to
- 1) Assistant Engineer, SD I, WD X, WRD, Quepem- Goa.
 - 2) The Executive Engineer, Works Division X, WRD, Pajimol- Sanguem- Goa.
 - 3) The Executive Engineer, Works Division XI, WRD, Rawanfond- Goa.
 - 4) The Surveyor of Works,Quality Control, C.P.O.,Water Resources Dept., Sinchai Bhavan,Alto Porvorim-Goa.
 - 5) Office File.