

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of side protection wall in Sy.No. 129/2 and 129/2B at Sonfatar, Xeldem village of Quepem Taluka.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F. 116/07/2024						226.67		No. WRD/SD V/WD XII/ F.70/26/2025-26. DATED: 30-04-2025
	F. 116/08/2024	21-04-2025	19-05-2025	Foundation	1.2.4	210 kg/cm2	235.56	226.67	
	F. 116/09/2024						217.78		
1.2	F. 116/10/2024						231.11		
	F. 116/11/2024	21-04-2025	19-05-2025	Foundation	1.2.4	210 kg/cm2	226.67	229.63	do
	F. 116/12/2024						231.11		
1.3	F. 116/13/2024						213.33		
	F. 116/14/2024	21-04-2025	19-05-2025	Foundation	1.2.4	210 kg/cm2	235.56	225.19	do
	F. 116/15/2024						226.67		
2.1	F. 116/16/2024						222.22		
	F. 116/17/2024	22-04-2025	20-05-2025	Foundation	1.2.4	210 kg/cm2	226.67	226.67	do
	F. 116/18/2024						231.11		
2.2	F. 116/19/2024						235.56		
	F. 116/20/2024	22-04-2025	20-05-2025	Foundation	1.2.4	210 kg/cm2	231.11	226.67	do
	F. 116/21/2024						213.33		
2.3	F. 116/22/2024						231.11		
	F. 116/23/2024	22-04-2025	20-05-2025	Foundation	1.2.4	210 kg/cm2	226.67	228.15	do
	F. 116/24/2024						226.67		
3.1	F. 116/25/2024						235.56		
	F. 116/26/2024	23-04-2025	21-05-2025	Foundation	1.2.4	210 kg/cm2	231.11	231.11	do
	F. 116/27/2024						226.67		
3.2	F. 116/28/2024						240.00		
	F. 116/29/2024	23-04-2025	21-05-2025	Foundation	1.2.4	210 kg/cm2	217.78	229.63	do
	F. 116/30/2024						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of side protection wall in Sy.No. 129/2 and 129/2B at Sonfatar, Xeldem village of Quepem Taluka.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.3	F. 116/31/2024						240.00		No. WRD/SD V/WD XII/ F.70/26/2025-26. DATED: 30-04-2025
	F. 116/32/2024	23-04-2025	21-05-2025	Foundation	1.2.4	210 kg/cm2	222.22	231.11	
	F. 116/33/2024						231.11		
4.1	F. 116/34/2024						226.67		
	F. 116/35/2024	24-04-2025	22-05-2025	Foundation	1.2.4	210 kg/cm2	235.56	231.11	do
	F. 116/36/2024						231.11		
4.2	F. 116/37/2024						213.33		
	F. 116/38/2024	24-04-2025	22-05-2025	Foundation	1.2.4	210 kg/cm2	235.56	228.15	do
	F. 116/39/2024						235.56		
4.3	F. 116/40/2024						231.11		
	F. 116/41/2024	24-04-2025	22-05-2025	Foundation	1.2.4	210 kg/cm2	235.56	229.63	do
	F. 116/42/2024						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of side protection wall in Sy.No. 129/2 and 129/2B at Sonfatar, Xeldem village of Quepem Taluka.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F. 116/43/2024						226.67		No. WRD/SD V/WD XII/ F.70/ 40 /2025-26. DATED: 12-05-2025
	F. 116/44/2024	2/5/2025	30-05-2025	Superstructure	1.2.4	210 kg/cm2	231.11	228.15	
	F. 116/45/2024						226.67		
5.2	F. 116/46/2024						235.56		
	F. 116/47/2024	2/5/2025	30-05-2025	Superstructure	1.2.4	210 kg/cm2	213.11	225.11	do
	F. 116/48/2024						226.67		
5.3	F. 116/49/2024						226.67		
	F. 116/50/2024	2/5/2025	30-05-2025	Superstructure	1.2.4	210 kg/cm2	231.11	226.67	do
	F. 116/51/2024						222.22		
6.1	F. 116/52/2024						244.44		
	F. 116/53/2024	3/5/2025	31-05-2025	Superstructure	1.2.4	210 kg/cm2	235.56	234.07	do
	F. 116/54/2024						222.22		
6.2	F. 116/55/2024						226.67		
	F. 116/56/2024	3/5/2025	31-05-2025	Superstructure	1.2.4	210 kg/cm2	235.56	231.11	do
	F. 116/57/2024						231.11		
6.3	F. 116/58/2024						226.67		
	F. 116/59/2024	3/5/2025	31-05-2025	Superstructure	1.2.4	210 kg/cm2	222.22	229.63	do
	F. 116/60/2024						240.00		
7.1	F. 116/61/2024						231.11		
	F. 116/62/2024	5/5/2025	2/6/2025	Superstructure	1.2.4	210 kg/cm2	208.89	225.19	do
	F. 116/63/2024						235.56		
7.2	F. 116/64/2024						226.67		
	F. 116/65/2024	5/5/2025	2/6/2025	Superstructure	1.2.4	210 kg/cm2	231.11	226.67	do
	F. 116/66/2024						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

NAME OF THE WORK: Construction of side protection wall in Sy.No. 129/2 and 129/2B at Sonfatar, Xeldem village of Quepem Taluka.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
7.3	F. 116/67/2024						235.56		No. WRD/SD V/WD XII/ F.70/ 40 /2025-26. DATED: 12-05-2025
	F. 116/67/2024	5/5/2025	2/6/2025	Superstructure	1.2.4	210 kg/cm2	217.78	226.67	
	F. 116/68/2024						226.67		
8.1	F. 116/69/2024						226.67		
	F. 116/70/2024	6/5/2025	3/6/2025	Superstructure	1.2.4	210 kg/cm2	231.11	231.11	do
	F. 116/71/2024						235.56		
8.2	F. 116/72/2024						226.67		
	F. 116/73/2024	6/5/2025	3/6/2025	Superstructure	1.2.4	210 kg/cm2	235.56	229.63	do
	F. 116/74/2024						226.67		
8.3	F. 116/75/2024						240.00		
	F. 116/76/2024	6/5/2025	3/6/2025	Superstructure	1.2.4	210 kg/cm2	222.22	232.59	do
	F. 116/77/2024						235.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER