

NO.WRD/WDXI/SDIII/TECH/W.F.150/2024/2025-26/132

Dated:-27/05/25

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Urgent repairs to the collapsed portion on LHS of nallah near road side at Koplem Deulwada in Village Borim of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F. 150/06/2024						235.56		No. WRD/WD XI/ SD IV/
	F. 150/07/2024	18-04-2025	16-05-2025	For Foundation	1.2.4	210 kg/cm2	222.22	228.15	WF.CF/92/2025-26.
	F. 150/08/2024						226.67		DATED: 29-04-2025.
1.2	F. 150/09/2024						226.67		
	F. 150/10/2024	18-04-2025	16-05-2025	For Foundation	1.2.4	210 kg/cm2	231.11	226.67	do
	F. 150/11/2024						222.22		
2.1	F. 150/12/2024						235.56		
	F. 150/13/2024	19-04-2025	17-05-2025	For Foundation	1.2.4	210 kg/cm2	226.67	228.15	do
	F. 150/14/2024						222.22		
2.2	F. 150/15/2024						222.22		
	F. 150/16/2024	19-04-2025	17-05-2025	For Foundation	1.2.4	210 kg/cm2	240.00	229.63	do
	F. 150/17/2024						226.67		
2.3	F. 150/18/2024						231.11		
	F. 150/19/2024	19-04-2025	17-05-2025	For Foundation	1.2.4	210 kg/cm2	222.22	226.67	do
	F. 150/20/2024						226.67		
2.4	F. 150/21/2024						231.11		
	F. 150/22/2024	19-04-2025	17-05-2025	For Foundation	1.2.4	210 kg/cm2	235.56	228.15	do
	F. 150/23/2024						217.78		
3.1	F. 150/24/2024						231.11		
	F. 150/25/2024	20-04-2025	19-05-2025	For Foundation	1.2.4	210 kg/cm2	235.56	229.63	do
	F. 150/26/2024						222.22		
3.2	F. 150/27/2024						222.22		
	F. 150/28/2024	20-04-2025	19-05-2025	For Foundation	1.2.4	210 kg/cm2	226.67	226.67	do
	F. 150/29/2024						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Urgent repairs to the collapsed portion on LHS of nallah near road side at Koplem Deulwada in Village Borim of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.1	F. 150/30/2024						235.56		No. WRD/WD XI/ SD IV/ WF.CF/ 92 /2025-26. DATED: 29-04-2025.
	F. 150/31/2024	22-04-2025	20-05-2025	1st Lift	1.2.4	210 kg/cm2	213.33	226.67	
	F. 150/32/2024						231.11		
4.2	F. 150/33/2024						231.11		
	F. 150/34/2024	22-04-2025	20-05-2025	1st Lift	1.2.4	210 kg/cm2	231.11	228.15	do
	F. 150/35/2024						222.22		
4.3	F. 150/36/2024						222.22		
	F. 150/37/2024	22-04-2025	20-05-2025	1st Lift	1.2.4	210 kg/cm2	231.11	229.63	do
	F. 150/38/2024						235.56		
4.4	F. 150/39/2024						226.67		
	F. 150/40/2024	22-04-2025	20-05-2025	1st Lift	1.2.4	210 kg/cm2	235.56	231.11	do
	F. 150/41/2024						231.11		
5.1	F. 150/42/2024						235.56		
	F. 150/43/2024	24-04-2025	22-05-2025	2nd Lift	1.2.4	210 kg/cm2	231.11	229.63	do
	F. 150/44/2024						222.22		
5.2	F. 150/45/2024						226.67		
	F. 150/46/2024	24-04-2025	22-05-2025	2nd Lift	1.2.4	210 kg/cm2	222.22	226.67	do
	F. 150/47/2024						231.11		
5.3	F. 150/48/2024						226.67		
	F. 150/49/2024	24-04-2025	22-05-2025	2nd Lift	1.2.4	210 kg/cm2	231.11	228.15	do
	F. 150/50/2024						226.67		
5.4	F. 150/51/2024						235.56		
	F. 150/52/2024	24-04-2025	22-05-2025	2nd Lift	1.2.4	210 kg/cm2	217.78	226.67	do
	F. 150/53/2024						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Urgent repairs to the collapsed portion on LHS of nallah near road side at Koplem Deulwada in Village Borim of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
6.1	F. 150/54/2024						226.67		No. WRD/WD XI/ SD IV/ WF.CF/92/2025-26. DATED: 29-04-2025.
	F. 150/55/2024	25-04-2025	23-05-2025	3rd Lift	1.2.4	210 kg/cm2	222.22	226.67	
	F. 150/56/2024						231.11		
6.2	F. 150/57/2024						231.11		
	F. 150/58/2024	25-04-2025	23-05-2025	3rd Lift	1.2.4	210 kg/cm2	226.67	228.15	do
	F. 150/59/2024						226.67		
6.3	F. 150/60/2024						226.67		
	F. 150/61/2024	25-04-2025	23-05-2025	3rd Lift	1.2.4	210 kg/cm2	217.78	226.67	do
	F. 150/62/2024						235.56		
6.4	F. 150/63/2024						240.00		
	F. 150/64/2024	25-04-2025	23-05-2025	3rd Lift	1.2.4	210 kg/cm2	231.11	229.63	do
	F. 150/65/2024						217.78		
7.1	F. 150/66/2024						231.11		
	F. 150/67/2024	26-04-2025	24-05-2025	4th Lift	1.2.4	210 kg/cm2	226.67	226.67	do
	F. 150/68/2024						222.22		
7.2	F. 150/69/2024						231.11		
	F. 150/70/2024	26-04-2025	24-05-2025	4th Lift	1.2.4	210 kg/cm2	226.67	228.15	do
	F. 150/71/2024						226.67		
8.1	F. 150/72/2024						231.11		
	F. 150/73/2024	28-04-2025	26-05-2025	5th Lift	1.2.4	210 kg/cm2	222.22	226.67	do
	F. 150/74/2024						226.67		
8.2	F. 150/75/2024						235.56		
	F. 150/76/2024	28-04-2025	26-05-2025	5th Lift	1.2.4	210 kg/cm2	226.67	229.63	do
	F. 150/77/2024						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER