

NO.WRD/WDXI/SDIII/TECH/W.F.117/2024/2025-26/ 135 . Dated:-27/05/25

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of lake near Datta Mandir in Sy.No. 91/2 at Dattawadi in V.P. Sanvordem in Sanvordem Constituency.

SAMPLE SENT BY: AE, SD I, WD XII, WRD, Pajimol- Sanguem - Goa.

NAME OF THE AGENCY					TESTING PERIOD		28 days.		
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.117/06/2024						235.56		No.WRD/SD I/WDXII/
	F.117/07/2024	4/4/2025	2/5/2025	Wall Foundation	1.2.4	210 kg/cm2	222.22	228.15	F.47/14/2025-26.
	F.117/08/2024						226.67		DATED: 07-04-2025
1.2	F.117/09/2024						231.11		
	F.117/10/2024	4/4/2025	2/5/2025	Wall Foundation	1.2.4	210 kg/cm2	226.67	226.67	do
	F.117/11/2024						222.22		
1.3	F.117/12/2024						231.11		
	F.117/13/2024	4/4/2025	2/5/2025	Wall Foundation	1.2.4	210 kg/cm2	235.56	229.63	do
	F.117/14/2024						222.22		
2.1	F.117/15/2024						235.56		
	F.117/16/2024	4/4/2025	2/5/2025	Wall Foundation	1.2.4	210 kg/cm2	222.22	226.67	do
	F.117/17/2024						222.22		
2.2	F.117/18/2024						231.11		
	F.117/19/2024	4/4/2025	2/5/2025	Wall Foundation	1.2.4	210 kg/cm2	231.11	228.15	do
	F.117/20/2024						222.22		
2.3	F.117/21/2024						235.56		
	F.117/22/2024	4/4/2025	2/5/2025	Wall Foundation	1.2.4	210 kg/cm2	231.11	229.63	do
	F.117/23/2024						222.22		
3.1	F.117/24/2024						231.11		
	F.117/25/2024	4/4/2025	2/5/2025	Wall Foundation	1.2.4	210 kg/cm2	226.67	228.15	do
	F.117/26/2024						226.67		
3.2	F.117/27/2024						235.56		
	F.117/28/2024	4/4/2025	2/5/2025	Wall Foundation	1.2.4	210 kg/cm2	217.78	226.67	do
	F.117/29/2024						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of lake near Datta Mandir in Sy.No. 91/2 at Dattawadi in V.P. Sanvordem in Sanvordem Constituency.

SAMPLE SENT BY: AE, SD I, WD XII, WRD, Pajimol- Sanguem - Goa.

NAME OF THE AGENCY					TESTING PERIOD		28 days.		
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.3	F.117/30/2024						240.00		No.WRD/SD I/WDXII/
	F.117/31/2024	4/4/2025	2/5/2025	Wall Foundation	1.2.4	210 kg/cm2	217.78	228.15	F.47/14/2025-26.
	F.117/32/2024						226.67		DATED: 07-04-2025
4.1	F.117/33/2024						235.56		
	F.117/34/2024	5/4/2025	3/5/2025	Wall 1st Lift	1.2.4	210 kg/cm2	235.56	229.63	do
	F.117/35/2024						217.78		
4.2	F.117/36/2024						231.11		
	F.117/37/2024	5/4/2025	3/5/2025	Wall 1st Lift	1.2.4	210 kg/cm2	231.11	228.15	do
	F.117/38/2024						222.22		
4.3	F.117/39/2024						231.11		
	F.117/40/2024	5/4/2025	3/5/2025	Wall 1st Lift	1.2.4	210 kg/cm2	231.11	226.67	do
	F.117/41/2024						217.78		
5.1	F.117/42/2024						231.11		
	F.117/43/2024	5/4/2025	3/5/2025	Wall 1st Lift	1.2.4	210 kg/cm2	217.78	225.19	do
	F.117/44/2024						226.67		
5.2	F.117/45/2024						231.11		
	F.117/46/2024	5/4/2025	3/5/2025	Wall 1st Lift	1.2.4	210 kg/cm2	217.78	222.22	do
	F.117/47/2024						217.78		
5.3	F.117/48/2024						235.56		
	F.117/49/2024	5/4/2025	3/5/2025	Wall 1st Lift	1.2.4	210 kg/cm2	213.33	223.70	do
	F.117/50/2024						222.22		
6.1	F.117/51/2024						235.56		
	F.117/52/2024	5/4/2025	3/5/2025	Wall 1st Lift	1.2.4	210 kg/cm2	222.22	226.67	do
	F.117/53/2024						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of lake near Datta Mandir in Sy.No. 91/2 at Dattawadi in V.P. Sanvordem in Sanvordem Constituency.

SAMPLE SENT BY: AE, SD I, WD XII, WRD, Pajimol- Sanguem - Goa.

NAME OF THE AGENCY					TESTING PERIOD		28 days.		
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
6.2	F.117/54/2024						235.56		No.WRD/SD I/WDXII/
	F.117/55/2024	5/4/2025	3/5/2025	Wall 1st Lift	1.2.4	210 kg/cm2	217.78	223.71	F.47/14/2025-26.
	F.117/56/2024						217.78		DATED: 07-04-2025
6.3	F.117/57/2024						231.11		
	F.117/58/2024	5/4/2025	3/5/2025	Wall 1st Lift	1.2.4	210 kg/cm2	222.22	225.18	do
	F.117/59/2024						222.22		
7.1	F.117/60/2024						235.56		
	F.117/61/2024	5/4/2025	3/5/2025	Wall 1st Lift	1.2.4	210 kg/cm2	222.22	226.67	do
	F.117/62/2024						222.22		
7.2	F.117/63/2024						231.11		
	F.117/64/2024	5/4/2025	3/5/2025	Wall 1st Lift	1.2.4	210 kg/cm2	231.11	225.18	do
	F.117/65/2024						213.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of lake near Datta Mandir in Sy.No. 91/2 at Dattawadi in V.P. Sanvordem in Sanvordem Constituency.

SAMPLE SENT BY: AE, SD I, WD XII, WRD, Pajimol- Sanguem - Goa.

NAME OF THE AGENCY					TESTING PERIOD		28 days.		
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
8.1	F.117/66/2024						240.00		No.WRD/SD I/WDXII/
	F.117/67/2024	8/4/2025	6/5/2025	Wall & Steps 2nd Lift	1.2.4	210 kg/cm2	222.22	229.63	F.47/21/2025-26.
	F.117/68/2024						226.67		DATED: 11-04-2025
8.2	F.117/69/2024						235.56		
	F.117/70/2024	8/4/2025	6/5/2025	Wall & Steps 2nd Lift	1.2.4	210 kg/cm2	235.56	228.15	do
	F.117/71/2024						213.33		
8.3	F.117/72/2024						231.11		
	F.117/73/2024	8/4/2025	6/5/2025	Wall & Steps 2nd Lift	1.2.4	210 kg/cm2	231.11	226.67	do
	F.117/74/2024						217.78		
9.1	F.117/75/2024						231.11		
	F.117/76/2024	8/4/2025	6/5/2025	Wall & Steps 2nd Lift	1.2.4	210 kg/cm2	231.11	228.15	do
	F.117/77/2024						222.22		
9.2	F.117/78/2024						231.11		
	F.117/79/2024	8/4/2025	6/5/2025	Wall & Steps 2nd Lift	1.2.4	210 kg/cm2	222.22	226.67	do
	F.117/80/2024						226.67		
9.3	F.117/81/2024						231.11		
	F.117/82/2024	8/4/2025	6/5/2025	Wall & Steps 2nd Lift	1.2.4	210 kg/cm2	235.56	228.15	do
	F.117/83/2024						217.78		
10.1	F.117/84/2024						235.56		
	F.117/85/2024	8/4/2025	6/5/2025	Wall & Steps 2nd Lift	1.2.4	210 kg/cm2	226.67	226.67	do
	F.117/86/2024						217.78		
10.2	F.117/87/2024						235.56		
	F.117/88/2024	8/4/2025	6/5/2025	Wall & Steps 2nd Lift	1.2.4	210 kg/cm2	217.78	225.19	do
	F.117/89/2024						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of lake near Datta Mandir in Sy.No. 91/2 at Dattawadi in V.P. Sanvordem in Sanvordem Constituency.

SAMPLE SENT BY: AE, SD I, WD XII, WRD, Pajimol- Sanguem - Goa.

NAME OF THE AGENCY					TESTING PERIOD		28 days.		
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
11.1	F.117/90/2024						231.11		No.WRD/SD I/WDXII/
	F.117/91/2024	8/4/2025	6/5/2025	Wall & Steps 2nd Lift	1.2.4	210 kg/cm2	240.00	228.15	F.47/21/2025-26.
	F.117/92/2024						213.33		DATED: 11-04-2025
11.2	F.117/93/2024						235.56		
	F.117/94/2024	8/4/2025	6/5/2025	Wall & Steps 2nd Lift	1.2.4	210 kg/cm2	226.67	229.63	do
	F.117/95/2024						226.67		
12.1	F.117/96/2024						235.56		
	F.117/97/2024	9/4/2025	7/5/2025	Wall & Steps 3rd Lift	1.2.4	210 kg/cm2	231.11	226.67	do
	F.117/98/2024						213.33		
12.2	F.117/99/2024						231.11		
	F.117/100/2024	9/4/2025	7/5/2025	Wall & Steps 3rd Lift	1.2.4	210 kg/cm2	231.11	225.18	do
	F.117/101/2024						213.33		
13.1	F.117/102/2024						235.56		
	F.117/103/2024	9/4/2025	7/5/2025	Wall & Steps 3rd Lift	1.2.4	210 kg/cm2	226.67	226.67	do
	F.117/104/2024						217.78		
13.2	F.117/105/2024						240.00		
	F.117/106/2024	9/4/2025	7/5/2025	Wall & Steps 3rd Lift	1.2.4	210 kg/cm2	222.22	228.15	do
	F.117/107/2024						222.22		
14.1	F.117/108/2024						226.67		
	F.117/109/2024	10/4/2025	8/5/2025	Wall & Steps 3rd Lift	1.2.4	210 kg/cm2	235.56	229.63	do
	F.117/110/2024						226.67		
14.2	F.117/111/2024						231.11		
	F.117/112/2024	10/4/2025	8/5/2025	Wall & Steps 3rd Lift	1.2.4	210 kg/cm2	222.20	231.10	do
	F.117/113/2024						240.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of lake near Datta Mandir in Sy.No. 91/2 at Dattawadi in V.P. Sanvordem in Sanvordem Constituency.

SAMPLE SENT BY: AE, SD I, WD XII, WRD, Pajimol- Sanguem - Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
15.1	F.117/114/2024						231.11		No.WRD/SD I/WDXII/
	F.117/115/2024	10/4/2025	8/5/2025	Wall & Steps 3rd Lift	1.2.4	210 kg/cm2	231.11	226.67	F.47/21/2025-26.
	F.117/116/2024						217.78		DATED: 11-04-2025
15.2	F.117/117/2024						235.56		
	F.117/118/2024	10/4/2025	8/5/2025	Wall & Steps 3rd Lift	1.2.4	210 kg/cm2	231.11	228.15	do
	F.117/119/2024						217.78		
16.1	F.117/120/2024						231.11		
	F.117/121/2024	11/4/2025	9/5/2025	Tank Surrounding	1.2.4	210 kg/cm2	231.11	229.63	do
	F.117/122/2024						226.67		
16.2	F.117/123/2024						231.11		
	F.117/124/2024	11/4/2025	9/5/2025	Tank Surrounding	1.2.4	210 kg/cm2	235.56	229.63	do
	F.117/125/2024						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER