

NO: WRD /WD XI / SD III/ TECH/W.F. 96-Oct-2022/137 / 2023-24

Dated:07/06/2023

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah near Antonio Pobrina Dias e Falerio house at Aquem Baixo in Margao Constituency.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.96/06/2022						186.67		No. 322/SD III/ WD III/ WRD/23-24/89 DATED: 31-05-2023.
	F.96/07/2022	26-05-2023	2/6/2023	Ch.0 m to 60 m for RCC wall 1st Step	1.1.5.3	175 kg/cm2	177.78	183.71	
	F.96/08/2022						186.67		
1.2	F.96/09/2022						182.22		
	F.96/10/2022	26-05-2023	2/6/2023	Ch.0 m to 60 m for RCC wall 1st Step	1.1.5.3	175 kg/cm2	186.67	185.19	do
	F.96/11/2022						186.67		
2.1	F.96/12/2022						182.22		
	F.96/13/2022	30-05-2023	6/6/2023	Ch.0 m to 60 m for RCC wall 2nd Step	1.1.5.3	175 kg/cm2	191.11	186.67	do
	F.96/14/2022						186.67		
2.2	F.96/15/2022						186.67		
	F.96/16/2022	30-05-2023	6/6/2023	Ch.0 m to 60 m for RCC wall 2nd Step	1.1.5.3	175 kg/cm2	177.78	182.22	do
	F.96/17/2022						182.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER