

GOVERNMENT OF GOA
WATER RESOURCES DEPARTMENT
S.D.III., Works Div. XI, QUALITY CONTROL LABORATORY
Gogol - Margao - Goa.

No. WRD / WD XI / SDIII / TECH/ WF.46-Oct-2022 /141 / 2022-23.

dated: 01/03/2023

Name of the Work: Construction of Open Type Bandhara at Voilem Agond under Sy.No. 52/8 of Village Agonda under Water Resources Department in Canacona Taluka.

Sample Sent by: Assistant Engineer, SD II, WD XI, WRD, Canacona -Goa

Letter No: No. WRD/SD II/WD XI/F-8/4 /245/2022-23.

Dated:- 27-02-2023.

Received on: 28-02-2023

Date of Testing: 1/3/2023

REPORT

Sample No.	Type of Sample	Tested for	Result	Permissible value	REMARKS
F.46/01/2022	Coarse Sand	FM Silt & Clay Grading	2.394 1.80% Zone III	2.3 to 3.1 Upto 5% Zone I to III	
F.46/02/2022	Fine Sand	FM Silt & Clay Grading	3.028 1.80% Zone IV	2.3 to 3.1 Upto 5% Zone I to IV	
F.46/03/2022	Aggregate-20 mm	Grading		As per IS-383:2016	To get the 20mm graded aggregate nominal size blend
F.46/04/2022	Aggregate- 10 mm	Grading		As per IS-383:2016	20mm & 10 mm metal in 1:1 proportion.

Junior Engineer

Assistant Engineer

Copy submitted to

- 1) Assistant Engineer, SD II, WD XI, WRD, Canacona-Goa.
- 2) The Executive Engineer, Works Division XI, WRD, Rawanfond- Goa.
- 3) The Surveyor of Works, Quality Control, C.P.O., Water Resources Dept., Sinchai Bhavan, Alto Porvorim-Goa.
- 4) Office File