

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of open type bandhara at Katchiband Survey No. 45, Pirla in V.P Cavrem- Pirla in Sanguem Constituency

SAMPLE SENT BY: AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.22/06/2022						226.67		No. WRD/SD I/WD XII/
	F.22/07/2022	9/1/2023	6/2/2023	Cut off Up stream	1.2.4	210 kg/cm2	222.22	225.19	F. 47/339/22-23.
	F.22/08/2022						226.67		DATED: 27-01-2023.
2	F.22/09/2022						226.67		
	F.22/10/2022	9/1/2023	6/2/2023	Cut off Up stream	1.2.4	210 kg/cm2	231.11	228.15	do
	F.22/11/2022						226.67		
3	F.22/12/2022						226.67		
	F.22/13/2022	9/1/2023	6/2/2023	Cut off Up stream	1.2.4	210 kg/cm2	226.67	225.19	do
	F.22/14/2022						222.22		
4	F.22/15/2022						231.11		
	F.22/16/2022	10/1/2023	7/2/2023	Center Cut off	1.2.4	210 kg/cm2	235.56	232.59	do
	F.22/17/2022						231.11		
5	F.22/18/2022						235.56		
	F.22/19/2022	11/1/2023	8/2/2023	Down stream Cut off	1.2.4	210 kg/cm2	231.11	231.11	do
	F.22/20/2022						226.67		
6	F.22/21/2022						226.67		
	F.22/22/2022	13/1/2023	10/2/2023	Pier Foundation	1.2.4	210 kg/cm2	217.78	223.71	do
	F.22/23/2022						226.67		
7	F.22/24/2022						226.67		
	F.22/25/2022	13/1/2023	10/2/2023	Pier Foundation	1.2.4	210 kg/cm2	226.67	225.19	do
	F.22/26/2022						222.22		
8	F.22/27/2022						235.56		
	F.22/28/2022	18/1/2023	15/2/2023	Up stream retaining wall Foundation	1.2.4	210 kg/cm2	226.67	231.11	do
	F.22/29/2022						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of open type bandharaat Katchiband Survey No. 45, Pirla in VP Cavrem Pirla in Sanguem Constituency

SAMPLE SENT BY: AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
9	F.22/30/2022						226.67		No. WRD/SD I/WD XII/ F. 47/339/22-23. DATED: 27-01-2023.
	F.22/31/2022	18/1/2023	15/2/2023	UP Stream Apron	1.2.4	210 kg/cm2	231.11	229.63	
	F.22/32/2022						231.11		
10	F.22/33/2022						226.67		
	F.22/34/2022	19/1/2023	16/2/2023	KEY WALL, Abutment	1.2.4	210 kg/cm2	217.78	220.74	do
	F.22/35/2022						217.78		
11	F.22/36/2022						231.11		
	F.22/37/2022	21/1/2023	18/2/2023	Down stream Apron	1.2.4	210 kg/cm2	226.67	228.15	do
	F.22/38/2022						226.67		
12	F.22/39/2022						222.22		
	F.22/40/2022	21/1/2023	18/2/2023	step 1	1.2.4	210 kg/cm2	231.11	229.63	do
	F.22/41/2022						235.56		
13	F.22/42/2022						226.67		
	F.22/43/2022	21/1/2023	18/2/2023	step 1	1.2.4	210 kg/cm2	231.11	225.19	do
	F.22/44/2022						217.78		
14	F.22/45/2022						235.56		
	F.22/46/2022	21/1/2023	18/2/2023	step 1	1.2.4	210 kg/cm2	222.22	226.67	do
	F.22/47/2022						222.22		
15	F.22/48/2022						231.11		
	F.22/49/2022	21/1/2023	18/2/2023	step 1	1.2.4	210 kg/cm2	231.11	228.15	do
	F.22/50/2022						222.22		
16	F.22/51/2022						226.67		
	F.22/52/2022	21/1/2023	18/2/2023	step 1	1.2.4	210 kg/cm2	222.22	225.19	do
	F.22/53/2022						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of open type bandharaat Katchiband Survey No. 45, Pirla in VP Cavrem Pirla in Sanguem Constituency

SAMPLE SENT BY: AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
17	F.22/54/2022						222.22		No. WRD/SD I/WD XII/
	F.22/55/2022	23/1/2023	20/2/2023	D/s retaining wall	1.2.4	210 kg/cm2	231.11	228.15	F. 47/ 339 /22-23.
	F.22/56/2022						231.11		DATED: 27-01-2023.
18	F.22/57/2022						226.67		
	F.22/58/2022	23/1/2023	20/2/2023	D/s retaining wall	1.2.4	210 kg/cm2	231.11	229.63	do
	F.22/59/2022						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER