

NO: WRD /WD XI / SD III/ TECH/W.F. 33-2022/142 / 2022-23

Dated:01/03/2023

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization to the RHS bank of nallah near bridge at Postwada in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.33/11/2022						231.11		No. WRD/SD V/WD XII/ F.70/222/2022-23. DATED: 30-01-2023
	F.33/12/2022	17-01-2023	14-02-2023	Foundation	1.2.4	210 kg/cm2	226.67	231.11	
	F.33/13/2022						235.56		
1.2	F.33/14/2022						231.11		do
	F.33/15/2022	17-01-2023	14-02-2023	Foundation	1.2.4	210 kg/cm2	231.11	228.15	
	F.33/16/2022						222.22		
1.3	F.33/17/2022						231.11		do
	F.33/18/2022	17-01-2023	14-02-2023	Foundation	1.2.4	210 kg/cm2	226.67	229.63	
	F.33/19/2022						231.11		
2.1	F.33/20/2022						235.56		do
	F.33/21/2022	19-01-2023	16-02-2023	Foundation	1.2.4	210 kg/cm2	226.67	228.15	
	F.33/22/2022						222.22		
2.2	F.33/23/2022						235.56		do
	F.33/24/2022	19-01-2023	16-02-2023	Foundation	1.2.4	210 kg/cm2	231.11	229.63	
	F.33/25/2022						222.22		
2.3	F.33/26/2022						231.11		do
	F.33/27/2022	19-01-2023	16-02-2023	Foundation	1.2.4	210 kg/cm2	226.67	228.15	
	F.33/28/2022						226.67		
3.1	F.33/29/2022						226.67		do
	F.33/30/2022	21-01-2023	18-02-2023	Foundation	1.2.4	210 kg/cm2	231.11	226.67	
	F.33/31/2022						222.22		
3.2	F.33/32/2022						231.11		do
	F.33/33/2022	21-01-2023	18-02-2023	Foundation	1.2.4	210 kg/cm2	222.22	223.70	
	F.33/34/2022						217.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization to the RHS bank of nallah near bridge at Postwada in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.3	F.33/35/2022						226.67		No. WRD/WD XII/SD V/ F.70/222/2022-23. DATED: 30-01-2023
	F.33/36/2022	21-01-2023	18-02-2023	Foundation	1.2.4	210 kg/cm2	226.67	225.19	
	F.33/37/2022						222.22		
4.1	F.33/38/2022						231.11		
	F.33/39/2022	22-01-2023	19-02-2023	Foundation	1.2.4	210 kg/cm2	231.11	228.15	do
	F.33/40/2022						222.22		
4.2	F.33/41/2022						226.67		
	F.33/42/2022	22-01-2023	19-02-2023	Foundation	1.2.4	210 kg/cm2	231.11	229.63	do
	F.33/43/2022						231.11		
4.3	F.33/44/2022						217.78		
	F.33/45/2022	22-01-2023	19-02-2023	Foundation	1.2.4	210 kg/cm2	231.11	226.67	do
	F.33/46/2022						231.11		
5.1	F.33/47/2022						226.67		
	F.33/48/2022	24-01-2023	21-02-2023	Foundation	1.2.4	210 kg/cm2	231.11	231.11	do
	F.33/49/2022						235.56		
5.2	F.33/50/2022						231.11		
	F.33/51/2022	24-01-2023	21-02-2023	Foundation	1.2.4	210 kg/cm2	217.78	226.67	do
	F.33/52/2022						231.11		
5.3	F.33/53/2022						226.67		
	F.33/54/2022	24-01-2023	21-02-2023	Foundation	1.2.4	210 kg/cm2	222.22	226.67	do
	F.33/55/2022						231.11		
6.1	F.33/56/2022						222.22		
	F.33/57/2022	25-01-2023	22-02-2023	1st Lift	1.2.4	210 kg/cm2	217.78	222.22	do
	F.33/58/2022						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization to the RHS bank of nallah near bridge at Postwada in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
6.2	F.33/59/2022						222.22		No. WRD/WD XII/SD V/ F.70/222/2022-23. DATED: 30-01-2023
	F.33/60/2022	25-01-2023	22-02-2023	1st Lift	1.2.4	210 kg/cm2	222.22	223.70	
	F.33/61/2022						226.67		
6.3	F.33/62/2022						222.22		
	F.33/63/2022	25-01-2023	22-02-2023	1st Lift	1.2.4	210 kg/cm2	226.67	220.74	do
	F.33/64/2022						213.33		
7.1	F.33/65/2022						231.11		
	F.33/66/2022	26-01-2023	23-02-2023	1st Lift	1.2.4	210 kg/cm2	231.11	228.15	do
	F.33/67/2022						222.22		
7.2	F.33/68/2022						226.67		
	F.33/69/2022	26-01-2023	23-02-2023	1st Lift	1.2.4	210 kg/cm2	231.11	226.67	do
	F.33/70/2022						222.22		
7.3	F.33/71/2022						226.67		
	F.33/72/2022	26-01-2023	23-02-2023	1st Lift	1.2.4	210 kg/cm2	217.78	223.71	do
	F.33/73/2022						226.67		
8.1	F.33/74/2022						231.11		
	F.33/75/2022	28-01-2023	25-02-2023	1st Lift	1.2.4	210 kg/cm2	226.67	228.15	do
	F.33/76/2022						226.67		
8.2	F.33/77/2022						231.11		
	F.33/78/2022	28-01-2023	25-02-2023	1st Lift	1.2.4	210 kg/cm2	222.22	226.67	do
	F.33/79/2022						226.67		
9.2	F.33/80/2022						222.22		
	F.33/81/2022	30-01-2023	27-02-2023	2nd lift	1.2.4	210 kg/cm2	226.67	225.19	do
	F.33/82/2022						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization to the RHS bank of nallah near bridge at Postwada in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
9.2	F.33/83/2022						226.67		No. WRD/SD V/WD XII/
	F.33/84/2022	30-01-2023	27-02-2023	2nd lift	1.2.4	210 kg/cm2	226.67	223.71	F.70/222/2022-23.
	F.33/85/2022						217.78		DATED: 30-01-2023

JUNIOR ENGINEER.

ASSISTANT ENGINEER

NO: WRD /WD XI / SD III/ TECH/W.F. 33-2022/147 / 2022-23

Dated:04/03/2023

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization to the RHS bank of nallah near bridge at Postwada in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.33/86/2022						226.67		No. WRD/SD V/WD XII/
	F.33/87/2022	31-01-2023	28-02-2023	Top Lift	1.2.4	210 kg/cm2	222.22	225.19	F.70/228/2022-23.
	F.33/88/2022						226.67		DATED: 07-02-2023
1.2	F.33/89/2022						222.22		
	F.33/90/2022	31-01-2023	28-02-2023	Top Lift	1.2.4	210 kg/cm2	226.67	222.22	do
	F.33/91/2022						217.78		

1.3	F.33/92/2022						226.67		
	F.33/93/2022	31-01-2023	28-02-2023	Top Lift	1.2.4	210 kg/cm2	222.22	223.70	do
	F.33/94/2022						222.22		
2.1	F.33/95/2022						231.11		
	F.33/96/2022	2/2/2023	2/3/2023	Top Lift	1.2.4	210 kg/cm2	226.67	231.11	do
	F.33/97/2022						235.56		
2.2	F.33/98/2022						231.11		
	F.33/99/2022	2/2/2023	2/3/2023	Top Lift	1.2.4	210 kg/cm2	231.11	229.63	do
	F.33/100/2022						226.67		
2.3	F.33/101/2022						235.56		
	F.33/102/2022	2/2/2023	2/3/2023	Top Lift	1.2.4	210 kg/cm2	231.11	229.63	do
	F.33/103/2022						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Stabilization to the RHS bank of nallah near bridge at Postwada in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.1	F.33/104/2022						222.22		No. WRD/SD V/WD XII/
	F.33/105/2022	4/2/2023	4/3/2023	Top Lift	1.2.4	210 kg/cm2	226.67	225.19	F.70/228/2022-23.
	F.33/106/2022						226.67		DATED: 07-02-2023
3.2	F.33/107/2022						226.67		
	F.33/108/2022	4/2/2023	4/3/2023	Top Lift	1.2.4	210 kg/cm2	226.67	223.71	do
	F.33/109/2022						217.78		
	F.33/110/2022						226.67		

3.3	F.33/111/2022	4/2/2023	4/3/2023	Top Lift	1.2.4	210 kg/cm2	231.11	226.67	do
	F.33/112/2022						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER