

NO.WRD/WDXI/SDIII/TECH/W.F. 107-2024/2025-26/ 149

Dated:-04/06/2025

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall near Pratibha CHSL at Aquem Alto in Margao Constituency.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.107/06/2024						235.56		No. 368/SD III/ WD III/ WRD/25-26/55. DATED: 24-04-2025.
	F.107/07/2024	28-03-2025	25-04-2025	Foundation P.C.C	1.2.4	210 kg/cm2	240.00	232.59	
	F.107/08/2024						222.22		
1.2	F.107/09/2024						235.56		
	F.107/10/2024	28-03-2025	25-04-2025	Foundation P.C.C	1.2.4	210 kg/cm2	235.56	231.11	do
	F.107/11/2024						222.22		
2.1	F.107/12/2024						280.00		
	F.107/13/2024	1/4/2025	29-04-2025	Side Wall	1.1.5.3	265 kg/cm2	284.44	284.44	do
	F.107/14/2024						288.89		
2.2	F.107/15/2024						293.33		
	F.107/16/2024	1/4/2025	29-04-2025	Side Wall	1.1.5.3	265 kg/cm2	280.00	282.96	do
	F.107/17/2024						275.56		
3.1	F.107/18/2024						297.78		
	F.107/19/2024	3/4/2025	2/5/2025	Side Wall	1.1.5.3	265 kg/cm2	266.67	280.00	do
	F.107/20/2024						275.56		
3.2	F.107/21/2024						288.89		
	F.107/22/2024	3/4/2025	2/5/2025	Side Wall	1.1.5.3	265 kg/cm2	280.00	278.52	do
	F.107/23/2024						266.67		
4.1	F.107/24/2024						293.33		
	F.107/25/2024	5/4/2025	3/5/2025	Side Wall	1.1.5.3	265 kg/cm2	275.56	281.48	do
	F.107/26/2024						275.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall near Pratibha CHSL at Aquem Alto in Margao Constituency.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.2	F.107/27/2024						293.33		No. 368/SD III/ WD III/ WRD/25-26/55. DATED: 24-04-2025.
	F.107/28/2024	5/4/2025	3/5/2025	Side Wall	1.1.5.3	265 kg/cm2	266.67	280.00	
	F.107/29/2024						280.00		
5.1	F.107/30/2024						288.89		
	F.107/31/2024	7/4/2025	5/5/2025	Side Wall	1.1.5.3	265 kg/cm2	284.44	285.92	do
	F.107/29/2024						284.44		
5.2	F.107/30/2024						288.89		
	F.107/31/2024	7/4/2025	5/5/2025	Side Wall	1.1.5.3	265 kg/cm2	280.00	282.96	do
	F.107/32/2024						280.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER