

NO: WRD /WD XI / SD III/ TECH/W.F. 39-Oct-2022/152 /2022-23

Dated: 08/03/2023

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of protection wall to Buthfond OTB canal at Malkarnem in Sanguem.

**SAMPLE SENT BY:** AE, SD I, WD XII, WRD, Pajimol- Sanguem - Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.39/11/2022						235.56		No. WRD/SD I/WD XII/ F.47/352/2022-23. <b>DATED: 08-02-2023</b>
	F.39/12/2022	4/2/2023	4/3/2023	Foundation Ch. 0.00 m to 9.00 m	1.2.4	210 kg/cm2	231.11	234.08	
	F.39/13/2022						235.56		
2	F.39/14/2022						231.11		do
	F.39/15/2022	6/2/2023	6/3/2023	Foundation Ch. 9.00 m to 18.50 m	1.2.4	210 kg/cm2	226.67	228.15	
	F.39/16/2022						226.67		
3	F.39/17/2022						226.67		do
	F.39/18/2022	7/2/2023	8/3/2023	Foundation Ch. 18.50 m to 30.00 m	1.2.4	210 kg/cm2	235.56	231.11	
	F.39/19/2022						231.11		
4	F.39/20/2022						222.22		do
	F.39/21/2022	7/2/2023	8/3/2023	1st Lift wall Ch.0.00 m to 4.00 m	1.2.4	210 kg/cm2	231.11	226.67	
	F.39/22/2022						226.67		
5	F.39/23/2022						235.56		do
	F.39/24/2022	7/2/2023	8/3/2023	1st Lift wall Ch.4.00 m to 8.00 m	1.2.4	210 kg/cm2	222.22	228.15	
	F.39/25/2022						226.67		
6	F.39/26/2022						231.11		do
	F.39/27/2022	7/2/2023	8/3/2023	1st Lift wall Ch.8.00 m to 16.00 m	1.2.4	210 kg/cm2	231.11	229.63	
	F.39/28/2022						226.67		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**