

NO: WRD /WD XI / SD III/ TECH/W.F. 96-Oct-2022/158 / 2023-24

Dated:27/06/2023

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Improvement of nallah near Antonio Pobrina Dias e Falerio house at Aquem Baixo in Margao Constituency.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1	F.96/18/2022						226.67		No. 322/SD III/ WD III/ WRD/23-24/89 DATED: 31-05-2023.
	F.96/19/2022	19-05-2023	16-06-2023	Ch.0 m to 60 m fdn of wall	1.2.4	210 kg/cm ²	231.11	229.63	
	F.96/20/2022						231.11		
2.1	F.96/21/2022						293.33		
	F.96/22/2022	23-05-2023	20-06-2023	Ch.0 m to 60 m Fdn Bed block RCC	1.1.5.3	265 kg/cm ²	297.78	294.81	do
	F.96/23/2022						293.33		
2.2	F.96/24/2022						288.89		
	F.96/25/2022	23-05-2023	20-06-2023	Ch.0 m to 60 m Fdn Bed block RCC	1.1.5.3	265 kg/cm ²	293.33	293.33	do
	F.96/26/2022						297.78		
3.1	F.96/27/2022						288.89		
	F.96/28/2022	26-05-2023	23-06-2023	Ch.0 m to 60 m for RCC wall 1st Step	1.1.5.3	265 kg/cm ²	297.78	290.37	do
	F.96/29/2022						284.44		
3.2	F.96/30/2022						297.78		
	F.96/31/2022	26-05-2023	23-06-2023	Ch.0 m to 60 m for RCC wall 1st Step	1.1.5.3	265 kg/cm ²	288.89	293.33	do
	F.96/32/2022						293.33		
4.1	F.96/33/2022						288.89		
	F.96/34/2022	30-05-2023	27-06-2023	Ch.0 m to 60 m for RCC wall 2nd Step	1.1.5.3	265 kg/cm ²	284.44	287.41	do
	F.96/35/2022						288.89		
4.2	F.96/36/2022						293.33		
	F.96/37/2022	30-05-2023	27-06-2023	Ch.0 m to 60 m for RCC wall 2nd Step	1.1.5.3	265 kg/cm ²	284.44	288.89	do
	F.96/38/2022						288.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER