

NO: WRD /WD XI / SD III/ TECH/W.F. 87-Oct-2022/ 164/ 2023-24

Dated:27/06/2023

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Improvement and Development to the Swami Bandhara at Pallolem in ward No. X in Canacona Muncipal Council.

SAMPLE SENT BY: AE, SD II, WD XI, WRD, Canacona- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.87/06/2022						288.89		No. WRD/SD II/WD XI/ F.8/28/2023-24. DATED: 15-05-2023.
	F.87/07/2022	10/5/2023	7/6/2023	Pier cap and foot bridge slab	1.1.5.3	265 kg/cm2	284.44	288.89	
	F.87/08/2022						293.33		
1.2	F.87/09/2022						288.89		
	F.87/10/2022	10/5/2023	7/6/2023	Pier cap and foot bridge slab	1.1.5.3	265 kg/cm2	293.33	290.37	do
	F.87/11/2022						288.89		
2.1	F.87/12/2022						235.56		
	F.87/13/2022	13-05-2023	10/6/2023	Sluice gate foundation	1.2.4	210 kg/cm2	222.22	229.63	do
	F.87/14/2022						231.11		
2.2	F.87/15/2022						226.67		
	F.87/16/2022	13-05-2023	10/6/2023	Sluice gate foundation	1.2.4	210 kg/cm2	226.67	228.15	do
	F.87/17/2022						231.11		
2.3	F.87/18/2022						235.56		
	F.87/19/2022	13-05-2023	10/6/2023	Sluice gate foundation	1.2.4	210 kg/cm2	231.11	231.11	do
	F.87/20/2022						226.67		
2.4	F.87/21/2022						226.67		
	F.87/22/2022	13-05-2023	10/6/2023	Sluice gate foundation	1.2.4	210 kg/cm2	231.11	231.11	do
	F.87/23/2022						235.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Improvement and Development to the Swami Bandhara at Pallolem in ward No. X in Canacona Municipal Council.

SAMPLE SENT BY: AE, SD II, WD XI, WRD, Canacona- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.1	F.87/24/2022						226.67		No. WRD/SD II/WD XI/
	F.87/25/2022	15-05-2023	13-06-2023	Sluice gate walls, foot bridge ramp,	1.2.4	210 kg/cm2	226.67	225.19	F.8/28/2023-24.
	F.87/26/2022			Pillar repair works			222.22		DATED: 15-05-2023.
3.2	F.87/27/2022						231.11		
	F.87/28/2022	15-05-2023	13-06-2023	Sluice gate walls, foot bridge ramp,	1.2.4	210 kg/cm2	226.67	228.15	do
	F.87/29/2022			Pillar repair works			226.67		
3.3	F.87/30/2022						231.11		
	F.87/31/2022	15-05-2023	13-06-2023	Sluice gate walls, foot bridge ramp,	1.2.4	210 kg/cm2	226.67	225.19	do
	F.87/32/2022			Pillar repair works			217.78		
3.4	F.87/33/2022						222.22		
	F.87/34/2022	15-05-2023	13-06-2023	Sluice gate walls, foot bridge ramp,	1.2.4	210 kg/cm2	226.67	226.67	do
	F.87/35/2022			Pillar repair works			231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER