

NO: WRD /WD XI / SD III/ TECH/W.F. 38-2022/169 / 2022-23

Dated:20/03/2023

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of flood protection wall to nallah sides in Sy.No.117/0 at Nirankal in Village Galwada Nirankar in Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.38/11/2022						231.11		No. WRD/WD XI/SD IV/ W.F.445/552/2022-23. DATED: 20-02-2023.
	F.38/12/2022	4/2/2023	4/3/2023	Foundation	1.2.4	210 kg/cm2	235.56	232.59	
	F.38/13/2022						231.11		
1.2	F.38/14/2022						226.67		do
	F.38/15/2022	4/2/2023	4/3/2023	Foundation	1.2.4	210 kg/cm2	231.11	231.11	
	F.38/16/2022						235.56		
2.1	F.38/17/2022						231.11		do
	F.38/18/2022	5/2/2023	5/3/2023	Foundation	1.2.4	210 kg/cm2	226.67	225.19	
	F.38/19/2022						217.78		
2.2	F.38/20/2022						226.67		do
	F.38/21/2022	5/2/2023	5/3/2023	Foundation	1.2.4	210 kg/cm2	231.11	229.63	
	F.38/22/2022						231.11		
3.1	F.38/23/2022						222.22		do
	F.38/24/2022	6/2/2023	6/3/2023	Foundation	1.2.4	210 kg/cm2	231.11	231.11	
	F.38/25/2022						240.00		
3.2	F.38/26/2022						231.11		do
	F.38/27/2022	6/2/2023	6/3/2023	Foundation	1.2.4	210 kg/cm2	235.56	232.59	
	F.38/28/2022						231.11		
4.1	F.38/29/2022						226.67		do
	F.38/30/2022	7/2/2023	7/3/2023	Foundation	1.2.4	210 kg/cm2	222.22	225.19	
	F.38/31/2022						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of flood protection wall to nallah sides in Sy.No.117/0 at Nirankal in Village Galwada Nirankar in Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.2	F.38/32/2022						226.67		No. WRD/WD XI/SD IV/ W.F.445/552/2022-23. DATED: 20-02-2023.
	F.38/33/2022	7/2/2023	7/3/2023	Foundation	1.2.4	210 kg/cm2	217.78	223.71	
	F.38/34/2022						226.67		
5.1	F.38/35/2022						231.11		
	F.38/36/2022	8/2/2023	8/3/2023	Foundation	1.2.4	210 kg/cm2	226.67	226.67	do
	F.38/37/2022						222.22		
5.2	F.38/38/2022						226.67		
	F.38/39/2022	8/2/2023	8/3/2023	Foundation	1.2.4	210 kg/cm2	226.67	228.15	do
	F.38/40/2022						231.11		
6	F.38/41/2022						217.78		
	F.38/42/2022	13-02-2023	13-03-2023	Horizontal band	1.2.4	210 kg/cm2	222.22	220.74	do
	F.38/43/2022						222.22		
7	F.38/44/2022						226.67		
	F.38/45/2022	14-02-2023	14-03-2023	Horizontal band	1.2.4	210 kg/cm2	217.78	219.26	do
	F.38/46/2022						213.33		
8	F.38/47/2022						222.22		
	F.38/48/2022	18-02-2023	18-03-2023	Horizontal band	1.2.4	210 kg/cm2	231.11	223.70	do
	F.38/49/2022						217.78		
9	F.38/50/2022						226.67		
	F.38/51/2022	19-02-2023	20-03-2023	Horizontal band	1.2.4	210 kg/cm2	213.33	220.74	do
	F.38/52/2022						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER