

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction and protection of retaining wall (right hand side) for nallah from Maruti temple to hill side (Om Divine) building at Mangor Hill Baina in Vasco Constituency.

SAMPLE SENT BY: AE, SD II, WD II, WRD, Gogal- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.48/05/2022						222.22		No. WRD/SD II/WD II/
	F.48/06/2022	13/2/2023	13/03/2023	Retaining wall foundation	1.2.4	210 kg/cm2	231.11	226.67	F.03/232/2022-23.
	F.48/07/2022						226.67		DATED: 08-02-2023.
1.1	F.48/08/2022						226.67		
	F.48/09/2022	13/2/2023	13/03/2023	Retaining wall foundation	1.2.4	210 kg/cm2	226.67	228.15	do
	F.48/10/2022						231.11		
2	F.48/11/2022						231.11		
	F.48/12/2022	14/2/2023	14/03/2023	Retaining wall foundation	1.2.4	210 kg/cm2	235.56	231.11	do
	F.48/13/2022						226.67		
2.1	F.48/14/2022						231.11		
	F.48/15/2022	14/2/2023	14/03/2023	Retaining wall foundation	1.2.4	210 kg/cm2	226.67	229.63	do
	F.48/16/2022						231.11		
3	F.48/17/2022						226.67		
	F.48/18/2022	15/2/2023	15/03/2023	Retaining wall 1st lift	1.2.4	210 kg/cm2	222.22	225.19	do
	F.48/19/2022						226.67		
3.1	F.48/20/2022						217.78		
	F.48/21/2022	15/2/2023	15/03/2023	Retaining wall 1st lift	1.2.4	210 kg/cm2	226.67	223.71	do
	F.48/22/2022						226.67		
4	F.48/23/2022						231.11		
	F.48/24/2022	16/02/2023	16/03/2023	Retaining wall 1st lift	1.2.4	210 kg/cm2	226.67	225.19	do
	F.48/25/2022						217.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

Construction and protection of retaining wall (right hand side) for nallah from Maruti temple to hill side (Om Divine) building at Mangor Hill Baina

NAME OF THE WORK: in Vasco Constituency.

SAMPLE SENT BY: AE, SD II, WD II, WRD, Gogal- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.1	F.48/26/2022						226.67		No. WRD/SD II/WD II/ F.03/232/2022-23. DATED: 08-02-2023.
	F.48/27/2022	16/02/2023	16/03/2023	Retaining wall 1st lift	1.2.4	210 kg/cm2	222.22	223.70	
	F.48/28/2022						222.22		
5	F.48/29/2022						231.11		
	F.48/30/2022	17/2/2023	17/03/2023	Retaining wall IInd lift	1.2.4	210 kg/cm2	240.00	232.59	do
	F.48/31/2022						226.67		
5.1	F.48/32/2022						231.11		
	F.48/33/2022	17/2/2023	17/03/2023	Retaining wall IInd lift	1.2.4	210 kg/cm2	231.11	229.63	do
	F.48/34/2022						226.67		
6	F.48/35/2022						235.56		
	F.48/36/2022	18/02/2013	18/03/2013	Retaining wall IInd lift	1.2.4	210 kg/cm2	222.22	228.15	do
	F.48/37/2022						226.67		
6.1	F.48/38/2022						231.11		
	F.48/39/2022	18/02/2013	18/03/2013	Retaining wall IInd lift	1.2.4	210 kg/cm2	226.67	226.67	do
	F.48/40/2022						222.22		
7	F.48/41/2022						235.56		
	F.48/42/2022	20/2/2023	20/3/2023	Retaining wall IIIrd lift	1.2.4	210 kg/cm2	231.11	228.15	do
	F.48/43/2022						217.78		
7.1	F.48/44/2022						231.11		
	F.48/45/2022	20/2/2023	20/3/2023	Retaining wall IIIrd lift	1.2.4	210 kg/cm2	226.67	226.67	do
	F.48/46/2022						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER