

NO: WRD /WD XI / SD III/ TECH/W.F. 47-Oct-2022/175 / 2022-23

Dated:23/03/2023

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Protection to nallah bank in survey No.161/1 V.P. Querim in Priol Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1.1	F.47/06/2022						155.56		No. WRD/WD XI/SD IV/ F.CF/604/2022-23. DATED: 15-03-2023.
	F.47/07/2022	9/3/2023	16-03-2023	for foundation	1.2.4	140 kg/cm ²	151.11	154.08	
	F.47/08/2022						155.56		
1.2	F.47/09/2022						151.11		
	F.47/10/2022	9/3/2023	16-03-2023	for foundation	1.2.4	140 kg/cm ²	160.00	154.07	do
	F.47/11/2022						151.11		
2	F.47/12/2022						146.67		
	F.47/13/2022	10/3/2023	17-03-2023	for foundation	1.2.4	140 kg/cm ²	155.56	151.11	do
	F.47/14/2022						151.11		
3	F.47/15/2022						155.56		
	F.47/16/2022	11/3/2023	18-03-2023	for foundation	1.2.4	140 kg/cm ²	160.00	152.59	do
	F.47/17/2022						142.22		
4.1	F.47/18/2022						151.11		
	F.47/19/2022	12/3/2023	20-03-2023	Above foundation	1.2.4	140 kg/cm ²	146.67	149.63	do
	F.47/20/2022						151.11		
4.2	F.47/21/2022						155.56		
	F.47/22/2022	12/3/2023	20-03-2023	Above foundation	1.2.4	140 kg/cm ²	151.11	152.59	do
	F.47/23/2022						151.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Protection to nallah bank in survey No.161/1 V.P. Querim in Priol Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.47/24/2022						164.44		No. WRD/WD XI/SD IV/ F.CV/604/2022-23. DATED: 15-03-2023.
	F.47/25/2022	13/3/2023	20-03-2023	Above foundation	1.2.4	140 kg/cm2	155.56	160.00	
	F.47/26/2022						160.00		
5.2	F.47/27/2022						155.56		do
	F.47/28/2022	13/3/2023	20-03-2023	Above foundation	1.2.4	140 kg/cm2	160.00	157.04	
	F.47/29/2022						155.56		
6.1	F.47/30/2022						146.67		do
	F.47/31/2022	14/3/2023	21-03-2023	Above foundation	1.2.4	140 kg/cm2	155.56	148.15	
	F.47/32/2022						142.22		
6.2	F.47/33/2022						151.11		do
	F.47/34/2022	14/3/2023	21-03-2023	Above foundation	1.2.4	140 kg/cm2	146.67	149.63	
	F.47/35/2022						151.11		
7.1	F.47/36/2022						155.56		do
	F.47/37/2022	15/3/2023	23-03-2023	Above foundation	1.2.4	140 kg/cm2	155.56	157.04	
	F.47/38/2022						160.00		
7.2	F.47/39/2022						155.56		do
	F.47/40/2022	15/3/2023	23-03-2023	Above foundation	1.2.4	140 kg/cm2	151.11	155.56	
	F.47/41/2022						160.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER