

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Providing RCC canal lining to minor M1 canal between Ch. 1.500km to 2.400 km in Cacora Village of Quepem Taluka.

SAMPLE SENT BY: AE, SD I, WD X, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.43/05/2022						111.11		No. WRD/WD X/SD I/ W.F.1/222/2022-23. DATED: 22-02-2023
	F.43/06/2022	22-02-2023	22-03-2023	PCC for canal lining	1.3.6	100 kg/cm2	111.11	109.63	
	F.43/07/2022						106.67		
1.2	F.43/08/2022						111.11		do
	F.43/09/2022	22-02-2023	22-03-2023	PCC for canal lining	1.3.6	100 kg/cm2	106.67	108.15	
	F.43/10/2022						106.67		
2.1	F.43/11/2022						288.89		No. WRD/WD X/SD I/ W.F.1/225/2022-23. DATED: 24-02-2023
	F.43/12/2022	24-02-2023	24-03-2023	RCC for canal lining	1.1.5.3	265 kg/cm2	284.44	290.37	
	F.43/13/2022						297.78		
2.2	F.43/14/2022						293.33		do
	F.43/15/2022	24-02-2023	24-03-2023	RCC for canal lining	1.1.5.3	265 kg/cm2	288.89	288.89	
	F.43/10/2022						284.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER