

NO.WRD/WDXI/SDIII/TECH/W.F.109/2023/2024-25/79

Dated:-20/05/2024

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement to nallah bank at Soshebhat behind office of V.P. Durbhat in Ponda Taluka.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.109/06/2023						231.11		No. WRD/WD XI/ SD IV/ W.F. 5087/54/2024-25. <b>DATED: 24-04-2024.</b>
	F.109/07/2023	7/4/2024	5/5/2024	Foundation	1.2.4	210 kg/cm2	231.11	226.67	
	F.109/08/2023						217.78		
1.2	F.109/09/2023						231.11		
	F.109/10/2023	7/4/2024	5/5/2024	Foundation	1.2.4	210 kg/cm2	222.22	225.18	do
	F.109/11/2023						222.22		
2.1	F.109/12/2023						235.56		
	F.109/13/2023	8/4/2024	6/5/2024	Foundation	1.2.4	210 kg/cm2	222.22	226.67	do
	F.109/14/2023						222.22		
2.2	F.109/15/2023						231.11		
	F.109/16/2023	8/4/2024	6/5/2024	Foundation	1.2.4	210 kg/cm2	231.11	228.15	do
	F.109/17/2023						222.22		
3.1	F.109/18/2023						231.11		
	F.109/19/2023	10/4/2024	8/5/2024	Above Foundation	1.2.4	210 kg/cm2	213.33	225.18	do
	F.109/20/2023						231.11		
3.2	F.109/21/2023						231.11		
	F.109/22/2023	10/4/2024	8/5/2024	Above Foundation	1.2.4	210 kg/cm2	213.33	222.22	do
	F.109/23/2023						222.22		
4.1	F.109/24/2023						231.11		
	F.109/25/2023	12/4/2024	10/5/2024	Above Foundation	1.2.4	210 kg/cm2	222.22	226.67	do
	F.109/26/2023						226.67		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement to nallah bank at Soshebhat behind office of V.P. Durbhat in Ponda Taluka.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

**28 days.**

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.2	F.109/27/2023						226.67		No. WRD/WD XI/ SD IV/ W.F. 5087/54/2024-25. <b>DATED: 24-04-2024.</b>
	F.109/28/2023	12/4/2024	10/5/2024	Above Foundation	1.2.4	210 kg/cm2	231.11	228.15	
	F.109/29/2023						226.67		
5.1	F.109/30/2023						235.56		
	F.109/31/2023	13-04-2024	13-05-2024	Above Foundation	1.2.4	210 kg/cm2	222.22	226.67	do
	F.109/32/2023						222.22		
5.2	F.109/33/2023						226.67		
	F.109/34/2023	13-04-2024	13-05-2024	Above Foundation	1.2.4	210 kg/cm2	226.67	225.19	do
	F.109/35/2023						222.22		
6.1	F.109/36/2023						217.78		
	F.109/37/2023	15-04-2024	13-05-2024	Above Foundation	1.2.4	210 kg/cm2	231.11	223.70	do
	F.109/38/2023						222.22		
6.2	F.109/39/2023						235.56		
	F.109/40/2023	15-04-2024	13-05-2024	Above Foundation	1.2.4	210 kg/cm2	222.22	226.67	do
	F.109/41/2023						222.22		
7.1	F.109/42/2023						231.11		
	F.109/43/2023	16-04-2024	14-05-2024	Above Foundation	1.2.4	210 kg/cm2	226.67	225.19	do
	F.109/44/2023						217.78		
7.2	F.109/45/2023						231.11		
	F.109/46/2023	16-04-2024	14-05-2024	Above Foundation	1.2.4	210 kg/cm2	231.11	226.67	do
	F.109/47/2023						217.78		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**