

NO.WRD/WDXI/SDIII/TECH/W.F.99/2022/2023-24/184 . Dated:-12/07/2023

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of retaining wall for the nallah in Sy.No. 192/14 at Verna in Nuvem Constituency of Salcete Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.99/05/2022						231.11		No. WRD/ SD I/WD II/ F.Esst/307/23-24. DATED: 04-07-2023.
	F.99/06/2022	10/6/2023	8/7/2023	Foundation	1.2.4	210 kg/cm2	235.56	232.59	
	F.99/07/2022						231.11		
1.2	F.99/08/2022						222.22		do
	F.99/09/2022	10/6/2023	8/7/2023	Foundation	1.2.4	210 kg/cm2	231.11	229.63	
	F.99/10/2022						235.56		
2.1	F.99/11/2022						235.56		do
	F.99/12/2022	12/6/2023	10/7/2023	Foundation	1.2.4	210 kg/cm2	244.44	235.56	
	F.99/13/2022						226.67		
2.2	F.99/14/2022						231.11		do
	F.99/09/2022	12/6/2023	10/7/2023	Foundation	1.2.4	210 kg/cm2	231.11	232.59	
	F.99/10/2022						235.56		
3.1	F.99/11/2022						226.67		do
	F.99/12/2022	13-06-2023	11/7/2023	Wall	1.2.4	210 kg/cm2	222.22	226.67	
	F.99/13/2022						231.11		
3.2	F.99/14/2022						231.11		do
	F.99/15/2022	13-06-2023	11/7/2023	Wall	1.2.4	210 kg/cm2	226.67	228.15	
	F.99/16/2022						226.67		
4.1	F.99/17/2022						241.11		do
	F.99/18/2022	14-06-2023	12/7/2023	Wall	1.2.4	210 kg/cm2	222.22	232.96	
	F.99/19/2022						235.56		
4.2	F.99/20/2022						231.11		do
	F.99/21/2022	14-06-2023	12/7/2023	Wall	1.2.4	210 kg/cm2	226.67	231.11	
	F.99/22/2022						235.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER