

NO: WRD /WD XI / SD III/ TECH/W.F. 97-2022/186 / 2023-24

Dated:19/07/2023

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Development and rejuvenation of Nanda lake at Ghotmorod in Kakoda in Curchorem Contintuency under Amrit Sarovar Mission.

**SAMPLE SENT BY:** AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.97/06/2022						231.11		No. WRD/SD V/WD XII/ F.70/73/2023-24. DATED: 22-06-2023
	F.97/07/2022	8/6/2023	6/7/2023	Foundation	1.2.4	210 kg/cm2	226.67	231.11	
	F.97/08/2022						235.56		
1.2	F.97/09/2022						231.11		do
	F.97/10/2022	8/6/2023	6/7/2023	Foundation	1.2.4	210 kg/cm2	231.11	229.63	
	F.97/11/2022						226.67		
1.3	F.97/12/2022						231.11		do
	F.97/13/2022	8/6/2023	6/7/2023	Foundation	1.2.4	210 kg/cm2	213.33	225.18	
	F.97/14/2022						231.11		
1.4	F.97/15/2022						222.22		do
	F.97/16/2022	8/6/2023	6/7/2023	Foundation	1.2.4	210 kg/cm2	235.56	228.15	
	F.97/17/2022						226.67		
1.5	F.97/18/2022						226.67		do
	F.97/19/2022	8/6/2023	6/7/2023	Foundation	1.2.4	210 kg/cm2	240.00	232.59	
	F.97/20/2022						231.11		
1.6	F.97/21/2022						240.00		do
	F.97/22/2022	8/6/2023	6/7/2023	Foundation	1.2.4	210 kg/cm2	217.78	231.11	
	F.97/23/2022						235.56		
1.7	F.97/24/2022						226.67		do
	F.97/25/2022	8/6/2023	6/7/2023	Foundation	1.2.4	210 kg/cm2	226.67	228.15	
	F.97/26/2022						231.11		
1.8	F.97/27/2022						231.11		do
	F.97/28/2022	8/6/2023	6/7/2023	Foundation	1.2.4	210 kg/cm2	231.11	232.59	
	F.97/29/2022						235.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

## SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Development and rejuvenation of Nanda lake at Ghotmorod in Kakoda in Curchorem Contituency under Amrit Sarovar Mission.

**SAMPLE SENT BY:** AE, SD V, WD XII, WRD, Quepem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

**28 days.**

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
2.1	F.97/30/2022						226.67		No. WRD/WD XII/SD V/ F.70/73/2023-24. <b>DATED: 22-06-2023</b>
	F.97/31/2022	14-06-2023	12/7/2023	Super Structure	1.2.4	210 kg/cm2	222.22	225.19	
	F.97/32/2022						226.67		
2.2	F.97/33/2022						231.11		
	F.97/34/2022	14-06-2023	12/7/2023	Super Structure	1.2.4	210 kg/cm2	226.67	226.67	do
	F.97/35/2022						222.22		
2.3	F.97/36/2022						231.11		
	F.97/37/2022	14-06-2023	12/7/2023	Super Structure	1.2.4	210 kg/cm2	231.11	229.63	do
	F.97/38/2022						226.67		
2.4	F.97/39/2022						217.78		
	F.97/40/2022	14-06-2023	12/7/2023	Super Structure	1.2.4	210 kg/cm2	231.11	225.19	do
	F.97/41/2022						226.67		
2.5	F.97/42/2022						222.22		
	F.97/43/2022	14-06-2023	12/7/2023	Super Structure	1.2.4	210 kg/cm2	231.11	226.67	do
	F.97/44/2022						226.67		
2.6	F.97/45/2022						222.22		
	F.97/46/2022	14-06-2023	12/7/2023	Super Structure	1.2.4	210 kg/cm2	226.67	223.70	do
	F.97/47/2022						222.22		
3.1	F.97/48/2022						231.11		
	F.97/49/2022	16-06-2023	14-07-2023	Super Structure	1.2.4	210 kg/cm2	231.11	232.59	do
	F.97/50/2022						235.56		
3.2	F.97/51/2022						235.56		
	F.97/52/2022	16-06-2023	14-07-2023	Super Structure	1.2.4	210 kg/cm2	222.22	229.63	do
	F.97/53/2022						231.11		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Development and rejuvenation of Nanda lake at Ghotmorod in Kakoda in Curchorem Contituency under Amrit Sarovar Mission.

**SAMPLE SENT BY:** AE, SD V, WD XII, WRD, Quepem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

**28 days.**

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
3.3	F.97/54/2022						231.11		No. WRD/WD XII/SD V/ F.70/73/2023-24. <b>DATED: 22-06-2023</b>
	F.97/55/2022	16-06-2023	14-07-2023	Super Structure	1.2.4	210 kg/cm <sup>2</sup>	208.89	225.19	
	F.97/56/2022						235.56		
3.4	F.97/57/2022						226.67		
	F.97/58/2022	16-06-2023	14-07-2023	Super Structure	1.2.4	210 kg/cm <sup>2</sup>	231.11	229.63	do
	F.97/59/2022						231.11		
4.1	F.97/60/2022						226.67		
	F.97/61/2022	19-06-2023	17-07-2023	Super Structure	1.2.4	210 kg/cm <sup>2</sup>	240.00	232.59	do
	F.97/62/2022						231.11		
4.2	F.97/63/2022						235.56		
	F.97/64/2022	19-06-2023	17-07-2023	Super Structure	1.2.4	210 kg/cm <sup>2</sup>	231.11	232.59	do
	F.97/65/2022						231.11		
4.3	F.97/66/2022						244.44		
	F.97/67/2022	19-06-2023	17-07-2023	Super Structure	1.2.4	210 kg/cm <sup>2</sup>	231.11	235.55	do
	F.97/68/2022						231.11		
5.1	F.97/69/2022						231.11		
	F.97/70/2022	21-06-2023	19-07-2023	Super Structure	1.2.4	210 kg/cm <sup>2</sup>	226.67	228.15	do
	F.97/71/2022						226.67		
5.2	F.97/72/2022						231.11		
	F.97/73/2022	21-06-2023	19-07-2023	Super Structure	1.2.4	210 kg/cm <sup>2</sup>	231.11	229.63	do
	F.97/74/2022						226.67		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**