

NO.WRD/WDXI/SDIII/TECH/W.F.153/2024/2025-26/197

. Dated:-30/06/2025

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of footbridge over existng OTB at Borimol Talem in V.P. Gaondongrem in Canacona Taluka.

SAMPLE SENT BY: AE, SD I, WD XI, WRD, Canacona- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.153/06/2024						293.33		No.WRD/WDXI/SD I/
	F.153/07/2024	14-05-2025	11/6/2025	Concreting for columns	1.1.5.3	265 kg/cm2	280.00	285.92	F.107-5/58/2025-26.
	F.153/08/2024						284.44		DATED: 20-05-2025
2.1	F.153/09/2024						297.78		
	F.153/10/2024	17-05-2025	16-06-2025	Concreting for beam, slab and steps	1.1.5.3	265 kg/cm2	275.55	284.44	do
	F.153/11/2024						280.00		
2.2	F.153/12/2024						288.89		
	F.153/13/2024	17-05-2025	16-06-2025	Concreting for beam, slab and steps	1.1.5.3	265 kg/cm2	280.00	287.41	do
	F.153/14/2024						293.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER