

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement & Development of bund at downstream of Orlim church in Benaulim Constituency.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.80/10/2022						222.22		No. WRD/SD I/WD II/ F./Camp/2023-24. <b>DATED: 16-06-2023</b>
	F.80/11/2022	5/6/2023	3/7/2023	Wall	1.2.4	210 kg/cm2	231.11	226.67	
	F.80/12/2022						226.67		
1.2	F.80/13/2022						231.11		
	F.80/14/2022	5/6/2023	3/7/2023	Wall	1.2.4	210 kg/cm2	226.67	225.19	do
	F.80/09/2022						217.78		
2.1	F.80/10/2022						235.56		
	F.80/11/2022	6/6/2023	4/7/2023	Wall	1.2.4	210 kg/cm2	226.67	228.15	do
	F.80/12/2022						222.22		
2.2	F.80/13/2022						235.56		
	F.80/14/2022	6/6/2023	4/7/2023	Wall	1.2.4	210 kg/cm2	226.67	231.11	do
	F.80/15/2022						231.11		
3.1	F.80/16/2022						231.11		
	F.80/17/2022	7/6/2023	5/7/2023	Foundation	1.2.4	210 kg/cm2	235.56	229.63	do
	F.80/18/2022						222.22		
3.2	F.80/19/2022						235.56		
	F.80/20/2022	7/6/2023	5/7/2023	Foundation	1.2.4	210 kg/cm2	231.11	231.11	do
	F.80/21/2022						226.67		
4.1	F.80/22/2022						235.56		
	F.80/23/2022	10/6/2023	10/7/2023	Wall	1.2.4	210 kg/cm2	226.67	229.63	do
	F.80/24/2022						226.67		
4.2	F.80/25/2022						231.11		
	F.80/26/2022	10/6/2023	10/7/2023	Wall	1.2.4	210 kg/cm2	222.22	231.11	do
	F.80/27/2022						240.00		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**