

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Anti Sea Erosion Wall from Vinod Sawant house to Audumbar Sirsaikar house in V.P Assagao in Siolim Constituency.

SAMPLE SENT BY: AE, SD I, WD I, WRD, Porvorim-Goa.

NAME OF THE AGENCY : Ashko Builders, H.no. 360,Dyna Soda Factory second Dandio, Talaulim, Navelim , Goa.

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
	1856						213.33		No. SDI/WD I/ WRD/
1	1857	24-12-2019	21-01-2020	Foundation & Plinth	1.2.4	210 kg/cm2	213.33	214.81	F.57/19-20/477
	1858						217.78		Dt.08/01/2020
	1859						208.89		
2	1860	24-12-2019	21-01-2020	Foundation & Plinth	1.2.4	210 kg/cm2	213.33	213.33	do
	1861						217.78		
	1862						226.67		
3	1863	26-12-2019	23-01-2020	Foundation & Plinth	1.2.4	210 kg/cm2	226.67	226.67	do
	1864						226.67		
	1865						226.67		
4	1866	26-12-2019	23-01-2020	Foundation & Plinth	1.2.4	210 kg/cm2	222.22	225.19	do
	1867						226.67		
	1868						222.22		
5	1869	27-12-2019	24-01-2020	Foundation & Plinth	1.2.4	210 kg/cm2	222.22	223.70	do
	1870						226.67		
	1871						222.22		
6	1872	27-12-2019	24-01-2020	Foundation & Plinth	1.2.4	210 kg/cm2	222.22	222.22	do
	1873						222.22		
	1874						226.67		
7	1875	28-12-2019	25-01-2020	Foundation & Plinth	1.2.4	210 kg/cm2	222.22	226.67	do
	1876						231.11		
	1877						226.67		
8	1878	28-12-2019	25-01-2020	Foundation & Plinth	1.2.4	210 kg/cm2	226.67	228.15	do
	1879						231.11		

TECHNICAL ASSISTANT
(Dhananjay R. Nagvenkar)

ASSISTANT ENGINEER
(Pravin C. Parsekar)

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Anti Sea Erosion Wall from Vinod Sawant house to Audumbar Sirsaikar house in V.P Assagao in Siolim Constituency.

SAMPLE SENT BY: AE, SD I, WD I, WRD, Porvorim-Goa.

NAME OF THE AGENCY : Ashko Builders, H.no. 360,Dyna Soda Factory second Dandio, Talaulim, Navelim , Goa.

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
	1880						226.67		No. SDI/WD I/ WRD/
1	1881	30-12-2019	27-01-2020	Foundation & Plinth	1.2.4	210 kg/cm2	231.11	229.63	F.57/19-20/477
	1882						231.11		Dt.08/01/2020
	1883						231.11		
2	1884	30-12-2019	27-01-2020	Foundation & Plinth	1.2.4	210 kg/cm2	231.11	229.63	do
	1885						226.67		
	1886						208.89		
3	1887	31-12-2019	28-01-2020	Foundation & Plinth	1.2.4	210 kg/cm2	213.33	211.85	do
	1888						213.33		
	1889						213.33		
4	1890	31-12-2019	28-01-2020	Foundation & Plinth	1.2.4	210 kg/cm2	208.89	213.33	do
	1891						217.78		
	1892						217.78		
5	1893	01-01-2020	29-01-2020	1st & 2nd Lift	1.2.4	210 kg/cm2	213.33	214.81	do
	1894						213.33		
	1895						213.33		
6	1896	01-01-2020	29-01-2020	1st & 2nd Lift	1.2.4	210 kg/cm2	213.33	213.33	do
	1897						213.33		
	1898						217.78		
7	1899	02-01-2020	30-01-2020	1st & 2nd Lift	1.2.4	210 kg/cm2	213.33	214.81	do
	1900						213.33		
	1901						213.33		
8	1902	02-01-2020	30-01-2020	1st & 2nd Lift	1.2.4	210 kg/cm2	213.33	213.33	do
	1903						213.33		

TECHNICAL ASSISTANT
(Dhananjay R. Nagvenkar)

ASSISTANT ENGINEER
(Pravin C. Parsekar)

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Anti Sea Erosion Wall from Vinod Sawant house to Audumbar Sirsaikar house in V.P Assagao in Siolim Constituency.

SAMPLE SENT BY: AE, SD I, WD I, WRD, Porvorim-Goa.

NAME OF THE AGENCY : Ashko Builders, H.no. 360,Dyna Soda Factory second Dandio, Talaulim, Navelim , Goa.

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
	1904						213.33		No. SDI/WD I/ WRD/
1	1905	03-01-2020	31-01-2020	1st & 2nd Lift	1.2.4	210 kg/cm2	217.78	214.81	F.57/19-20/477
	1906						213.33		Dt.08/01/2020
	1907						208.89		
2	1908	03-01-2020	31-01-2020	1st & 2nd Lift	1.2.4	210 kg/cm2	213.33	211.85	do
	1909						213.33		
	1910						213.33		
3	1911	04-01-2020	01-02-2020	1st & 2nd Lift	1.2.4	210 kg/cm2	217.78	216.30	do
	1912						217.78		
	1913						217.78		
4	1914	04-01-2020	01-02-2020	1st & 2nd Lift	1.2.4	210 kg/cm2	217.78	219.26	do
	1915						222.22		
	1916						217.78		
5	1917	06-01-2020	03-02-2020	1st & 2nd Lift	1.2.4	210 kg/cm2	217.78	217.78	do
	1918						217.78		
	1919						213.33		
6	1920	06-01-2020	03-02-2020	1st & 2nd Lift	1.2.4	210 kg/cm2	217.78	214.81	do
	1921						213.33		
	1922						208.89		
7	1923	07-01-2020	04-02-2020	1st & 2nd Lift	1.2.4	210 kg/cm2	213.33	213.33	do
	1924						217.78		
	1925						213.33		
8	1926	07-01-2020	04-02-2020	1st & 2nd Lift	1.2.4	210 kg/cm2	213.33	214.81	do
	1927						217.78		

TECHNICAL ASSISTANT
(Dhananjay R. Nagvenkar)

ASSISTANT ENGINEER
(Pravin C. Parsekar)