

NO.WRD/WDXI/SDIII/TECH/W.F. 01-2024/2024-25/202

. Dated:-22/11/2024

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Improvement of nallah side bank in Sy.No. 146/9 & 146/11 in Village Verna in Nuvem Constituency of Salcete Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.01/11/2024						226.67		No. WRD/ SD I/ WD II/ F. /camp/24-25. DATED: 22-10-2024.
	F.01/12/2024	14-10-2024	11/11/2024	Foundation	1.2.4	210 kg/cm2	226.67	228.15	
	F.01/13/2024						231.11		
1.2	F.01/14/2024						222.22		do
	F.01/15/2024	14-10-2024	11/11/2024	Foundation	1.2.4	210 kg/cm2	235.56	229.63	
	F.01/16/2024						231.11		
1.3	F.01/17/2024						240.00		do
	F.01/18/2024	14-10-2024	11/11/2024	Foundation	1.2.4	210 kg/cm2	231.11	229.63	
	F.01/19/2024						217.78		
1.4	F.01/20/2024						226.67		do
	F.01/21/2024	14-10-2024	11/11/2024	Foundation	1.2.4	210 kg/cm2	222.22	226.67	
	F.01/22/2024						231.11		
2.1	F.01/23/2024						235.56		do
	F.01/24/2024	15-10-2024	12/11/2024	Foundation	1.2.4	210 kg/cm2	240.00	229.63	
	F.01/25/2024						213.33		
2.2	F.01/26/2024						208.89		do
	F.01/27/2024	15-10-2024	12/11/2024	Foundation	1.2.4	210 kg/cm2	231.11	225.19	
	F.01/28/2024						235.56		
2.3	F.01/29/2024						231.11		do
	F.01/30/2024	15-10-2024	12/11/2024	Foundation	1.2.4	210 kg/cm2	226.67	231.11	
	F.01/31/2024						235.56		
2.4	F.01/32/2024						226.67		do
	F.01/33/2024	15-10-2024	12/11/2024	Foundation	1.2.4	210 kg/cm2	231.11	229.63	
	F.01/34/2024						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Improvement of nallah side bank in Sy.No. 146/9 & 146/11 in Village Verna in Nuvem Constituency of Salcete Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.1	F.01/35/2024						244.44		No. WRD/ SD I/ WD II/ F. /camp/24-25. DATED: 22-10-2024.
	F.01/36/2024	16-10-2024	13-11-2024	Foundation	1.2.4	210 kg/cm2	231.11	232.59	
	F.01/37/2024						222.22		
3.2	F.01/38/2024						226.67		do
	F.01/39/2024	16-10-2024	13-11-2024	Foundation	1.2.4	210 kg/cm2	235.56	234.08	
	F.01/40/2024						240.00		
3.3	F.01/41/2024						235.56		do
	F.01/42/2024	16-10-2024	13-11-2024	Foundation	1.2.4	210 kg/cm2	222.22	229.59	
	F.01/43/2024						231.00		
3.4	F.01/44/2024						231.00		do
	F.01/45/2024	16-10-2024	13-11-2024	Foundation	1.2.4	210 kg/cm2	235.56	232.56	
	F.01/46/2024						231.11		
4.1	F.01/47/2024						226.67		do
	F.01/49/2024	17-10-2024	14-11-2024	Foundation	1.2.4	210 kg/cm2	231.11	229.63	
	F.01/50/2024						231.11		
4.2	F.01/51/2024						217.78		do
	F.01/52/2024	17-10-2024	14-11-2024	Foundation	1.2.4	210 kg/cm2	240.00	229.63	
	F.01/53/2024						231.11		
4.3	F.01/54/2024						226.67		do
	F.01/55/2024	17-10-2024	14-11-2024	Foundation	1.2.4	210 kg/cm2	231.11	226.67	
	F.01/56/2024						222.22		
4.4	F.01/57/2024						235.56		do
	F.01/58/2024	17-10-2024	14-11-2024	Foundation	1.2.4	210 kg/cm2	226.67	228.15	
	F.01/59/2024						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah side bank in Sy.No. 146/9 & 146/11 in Village Verna in Nuvem Constituency of Salcete Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.5	F.01/60/2024						235.56		No. WRD/ SD I/ WD II/ F. /camp/24-25. DATED: 22-10-2024.
	F.01/61/2024	17-10-2024	14-11-2024	Foundation	1.2.4	210 kg/cm2	231.11	229.63	
	F.01/62/2024						222.22		
5.1	F.01/63/2024						244.44		
	F.01/64/2024	18-10-2024	15-11-2024	Foundation	1.2.4	210 kg/cm2	217.78	231.11	do
	F.01/65/2024						231.11		
5.2	F.01/66/2024						222.22		
	F.01/67/2024	18-10-2024	15-11-2024	Foundation	1.2.4	210 kg/cm2	231.11	229.63	do
	F.01/68/2024						235.56		
5.3	F.01/69/2024						226.67		
	F.01/70/2024	18-10-2024	15-11-2024	Foundation	1.2.4	210 kg/cm2	231.11	231.11	do
	F.01/71/2024						235.56		
5.4	F.01/72/2024						226.67		
	F.01/73/2024	18-10-2024	15-11-2024	Foundation	1.2.4	210 kg/cm2	231.11	232.59	do
	F.01/74/2024						240.00		
5.5	F.01/75/2024						235.56		
	F.01/76/2024	18-10-2024	15-11-2024	Foundation	1.2.4	210 kg/cm2	231.11	231.11	do
	F.01/77/2024						226.67		
6.1	F.01/78/2024						226.67		
	F.01/79/2024	19-10-2024	16-11-2024	Concrete band	1.2.4	210 kg/cm2	222.22	226.67	do
	F.01/80/2024						231.11		
6.2	F.01/81/2024						235.56		
	F.01/82/2024	19-10-2024	16-11-2024	Concrete band	1.2.4	210 kg/cm2	222.22	228.15	do
	F.01/83/2024						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah side bank in Sy.No. 146/9 & 146/11 in Village Verna in Nuvem Constituency of Salcete Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
6.3	F.01/84/2024						217.78		No. WRD/ SD I/ WD II/ F. /camp/24-25. DATED: 22-10-2024.
	F.01/85/2024	19-10-2024	16-11-2024	Concrete band	1.2.4	210 kg/cm2	226.67	226.67	
	F.01/86/2024						235.56		
7.1	F.01/87/2024						231.11		
	F.01/88/2024	21-10-2024	18-11-2024	Concrete band	1.2.4	210 kg/cm2	226.67	228.15	do
	F.01/89/2024						226.67		
7.2	F.01/90/2024						235.56		
	F.01/91/2024	21-10-2024	18-11-2024	Concrete band	1.2.4	210 kg/cm2	231.11	229.63	do
	F.01/92/2024						222.22		
7.3	F.01/93/2024						226.67		
	F.01/94/2024	21-10-2024	18-11-2024	Concrete band	1.2.4	210 kg/cm2	231.11	226.67	do
	F.01/95/2024						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER