

NO.WRD/WDXI/SDIII/TECH/W.F.201/2024/2025-26/213

Dated:-30/06/2025

GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Improvement to existing storage Irrigation tank in Sy.No. 154/1, Kulanwada, Savoi Verem in Priol Constituency of Ponda Taluka.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

**28 days.**

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.201/11/2024						293.33		No. WRD/WD XI/ SD IV/
	F.201/12/2024	2/6/2025	30-06-2025	For Foundation	1.1.5.3	265 kg/cm2	280.00	285.92	F. CF/235/2025-26.
	F.201/13/2024						284.44		<b>DATED: 30-06-2025.</b>
1.2	F.201/14/2024						288.89		
	F.201/15/2024	2/6/2025	30-06-2025	For Foundation	1.1.5.3	265 kg/cm2	288.89	287.41	do
	F.201/16/2024						284.44		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**