

NO.WRD/WDXI/SDIII/TECH/W.F. 206-2024/2025-26/ 225

. Dated:-8/8/2025

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Reconstruction of platform near Ganesh Visarjan site next to Saiba restaurant at Cuchelim, Mapusa ward 1 of Mapusa Constituency.

SAMPLE SENT BY: AE, SD II, WD I, WRD, Mapusa- Bardez- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.206/05/2024						231.11		No. WRD/ WD I/SD II/
	F.206/06/2024	7/7/2025	4/8/2025	Foundation	1.2.4	210 kg/cm2	235.56	231.11	F. 24/2025-26/275.
	F.206/07/2024						226.67		DATED: 04-08-2025
2	F.206/08/2024						217.78		
	F.206/09/2024	9/7/2025	6/8/2025	Super Structure	1.2.4	210 kg/cm2	235.56	228.15	do
	F.206/10/2024						231.11		
3	F.206/11/2024						222.22		
	F.206/12/2024	11/7/2025	8/8/2025	Super Structure	1.2.4	210 kg/cm2	231.11	229.63	do
	F.206/13/2024						235.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER