

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Retaining wall near St. Cruz chapel at Shirvodem in Margao Constituency.

**SAMPLE SENT BY:** AE, SD III, WD III, WRD, Gogol- Margao- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

**07 days.**

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.01/05/2023						146.67		No. 332/ SD III/ WD III/ WRD/23-24/ <b>305</b> . <b>DATED: 20-10-2023</b>
	F.01/06/2023	14-10-2023	21-10-2023	Retaining wall foundation	1.2.4	140 kg/cm2	151.11	146.67	
	F.01/07/2023						142.22		
1.2	F.01/08/2023						155.56		
	F.01/09/2023	14-10-2023	21-10-2023	Retaining wall foundation	1.2.4	140 kg/cm2	151.11	149.63	do
	F.01/10/2023						142.22		
2.1	F.01/11/2023						151.11		
	F.01/12/2023	17-10-2023	25-10-2023	Retaining wall 1st Lift	1.2.4	140 kg/cm2	146.67	151.11	do
	F.01/13/2023						155.56		
2.2	F.01/14/2023						151.11		
	F.01/15/2023	17-10-2023	25-10-2023	Retaining wall 1st Lift	1.2.4	140 kg/cm2	151.11	149.63	do
	F.01/16/2023						146.67		
3	F.01/17/2023						160.00		
	F.01/18/2023	19-10-2023	26-10-2023	Retaining wall final lift	1.2.4	140 kg/cm2	142.22	151.11	do
	F.01/19/2023						151.11		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**