

NO.WRD/WDXI/SDIII/TECH/W.F.12/2024/2024-25/232

. Dated:-16/12/24

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Providing flood control measures to the nallah at Bhanute Adulshe in V.P. Borim of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.12/11/2024						235.56		No. WRD/WD XI/ SD IV/ W.F 533/459/2024-25. DATED: 05-12-2024.
	F.12/12/2024	15-11-2024	13-12-2024	For Foundation	1.2.4	210 kg/cm2	226.67	231.11	
	F.12/13/2024						231.11		
1.2	F.12/14/2024						226.67		do
	F.12/15/2024	15-11-2024	13-12-2024	For Foundation	1.2.4	210 kg/cm2	231.11	228.15	
	F.12/16/2024						226.67		
1.3	F.12/17/2024						231.11		do
	F.12/18/2024	15-11-2024	13-12-2024	For Foundation	1.2.4	210 kg/cm2	235.56	226.67	
	F.12/19/2024						213.33		
1.4	F.12/20/2024						222.22		do
	F.12/21/2024	15-11-2024	13-12-2024	For Foundation	1.2.4	210 kg/cm2	240.00	229.63	
	F.12/22/2024						226.67		
2.1	F.12/23/2024						226.67		do
	F.12/24/2024	16-11-2024	16-12-2024	For Foundation	1.2.4	210 kg/cm2	240.00	229.63	
	F.12/25/2024						222.22		
2.2	F.12/26/2024						231.11		do
	F.12/27/2024	16-11-2024	16-12-2024	For Foundation	1.2.4	210 kg/cm2	235.56	228.15	
	F.12/28/2024						217.78		
2.3	F.12/29/2024						235.56		do
	F.12/30/2024	16-11-2024	16-12-2024	For Foundation	1.2.4	210 kg/cm2	231.11	229.63	
	F.12/31/2024						222.22		
2.4	F.12/32/2024						231.11		do
	F.12/33/2024	16-11-2024	16-12-2024	For Foundation	1.2.4	210 kg/cm2	240.00	231.11	
	F.12/34/2024						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Providing flood control measures to the nallah at Bhanute Adulshe in V.P. Borim of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.1	F.12/35/2024						226.67		No. WRD/WD XI/ SD IV/ W.F 533/ 459 /2024-25. DATED: 05-12-2024.
	F.12/36/2024	18-11-2024	16-12-2024	For Foundation	1.2.4	210 kg/cm2	231.11	228.15	
	F.12/37/2024						226.67		
3.2	F.12/38/2024						235.56		
	F.12/39/2024	18-11-2024	16-12-2024	For Foundation	1.2.4	210 kg/cm2	222.22	231.11	do
	F.12/40/2024						235.56		
4.1	F.12/41/2024						217.78		
	F.12/42/2024	19-11-2024	17-12-2024	For Foundation	1.2.4	210 kg/cm2	231.11	228.15	do
	F.12/43/2024						235.56		
4.2	F.12/44/2024						240.00		
	F.12/45/2024	19-11-2024	17-12-2024	For Foundation	1.2.4	210 kg/cm2	226.67	231.11	do
	F.12/46/2024						226.67		
4.3	F.12/47/2024						235.56		
	F.12/48/2024	19-11-2024	17-12-2024	For Foundation	1.2.4	210 kg/cm2	222.22	229.63	do
	F.12/49/2024						231.11		
4.4	F.12/50/2024						226.67		
	F.12/51/2024	19-11-2024	17-12-2024	For Foundation	1.2.4	210 kg/cm2	235.56	231.11	do
	F.12/52/2024						231.11		
5.1	F.12/53/2024						222.22		
	F.12/54/2024	20-11-2024	18-12-2024	For Foundation Base	1.2.4	210 kg/cm2	226.67	226.67	do
	F.12/55/2024						231.11		
5.2	F.12/56/2024						235.56		
	F.12/57/2024	20-11-2024	18-12-2024	For Foundation Base	1.2.4	210 kg/cm2	222.22	229.63	do
	F.12/58/2024						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Providing flood control measures to the nallah at Bhanute Adulshe in V.P. Borim of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.3	F.12/59/2024						235.56		No. WRD/WD XI/ SD IV/ W.F 533/459/2024-25. DATED: 05-12-2024.
	F.12/60/2024	20-11-2024	18-12-2024	For Foundation Base	1.2.4	210 kg/cm2	213.33	226.67	
	F.12/61/2024						231.11		
5.4	F.12/62/2024						240.00		do
	F.12/63/2024	20-11-2024	18-12-2024	For Foundation Base	1.2.4	210 kg/cm2	217.78	228.15	
	F.12/64/2024						226.67		
6.1	F.12/65/2024						226.67		do
	F.12/66/2024	21-11-2024	20-12-2024	For Foundation Base	1.2.4	210 kg/cm2	226.67	229.63	
	F.12/67/2024						235.56		
6.2	F.12/68/2024						231.11		do
	F.12/69/2024	21-11-2024	20-12-2024	For Foundation Base	1.2.4	210 kg/cm2	222.22	226.67	
	F.12/70/2024						226.67		
7.1	F.12/71/2024						231.11		do
	F.12/72/2024	27-11-2024	26-12-2024	For Middle band	1.2.4	210 kg/cm2	217.78	231.11	
	F.12/73/2024						244.44		
7.2	F.12/74/2024						231.11		do
	F.12/75/2024	27-11-2024	26-12-2024	For Middle band	1.2.4	210 kg/cm2	231.11	229.63	
	F.12/76/2024						226.67		
8.1	F.12/77/2024						235.56		do
	F.12/78/2024	3/12/2024	31-12-2024	For Top band	1.2.4	210 kg/cm2	222.22	226.67	
	F.12/79/2024						222.22		
8.2	F.12/80/2024						231.11		do
	F.12/81/2024	3/12/2024	31-12-2024	For Top band	1.2.4	210 kg/cm2	231.11	228.15	
	F.12/82/2024						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER