

NO: WRD /WD XI / SD III/ TECH/W.F. 04-Oct-2023/235 / 2023-24

Dated:14/11/2023

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to the RHS bank of nallah to protect side bank in Village Codar of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1	F.04/06/2023						146.67		No. WRD/WD XI/SD IV/ F.CF/438/2023-24. DATED: 08-11-2023
	F.04/07/2023	2/11/2023	9/11/2023	Foundation	1.2.4	140 kg/cm ²	155.56	148.15	
	F.04/08/2023						142.22		
2	F.04/09/2023						146.67		
	F.04/10/2023	4/11/2023	11/11/2023	Foundation	1.2.4	140 kg/cm ²	142.22	145.19	do
	F.04/11/2023						146.67		
3	F.04/12/2023						151.11		
	F.04/13/2023	6/11/2023	13-11-2023	Foundation	1.2.4	140 kg/cm ²	142.22	146.67	do
	F.04/14/2023						146.67		
4	F.04/15/2023						142.22		
	F.04/16/2023	7/11/2023	14-11-2023	Foundation	1.2.4	140 kg/cm ²	142.22	143.70	do
	F.04/17/2023						146.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER