

**GOVERNMENT OF GOA**  
**WATER RESOURCES DEPARTMENT**  
**S.D.III., Works Div. XI, QUALITY CONTROL LABORATORY**  
**Gogol - Margao - Goa.**

No. WRD / WD XI / SDIII / TECH / WF. 16-Oct-2023 / 245 /2023-24.

Dated: 25/11/2023

Name of the Work: Construction of nallah behind PM Dias residency Co-op housing Society Ltd., to Rajiv Shinkre house at Borda in Fatorda Constituency.

Sample Sent by: Assistant Engineer , SD III, WD III , WRD , Gogol- Margao - Goa.

Letter No: 333/SD III/WD III/WRD/23-24/340

Dated:- 22-11-2023

Received on: 22-11-2023

Date of Testing 24-11-2023

**REPORT**

Sample No.	Type of Sample	Tested for	Result	Permissible value	REMARKS
F.16/01/2023	Coarse Sand	FM Silt & Clay Grading	2.596 1.40% Zone III	2.3 to 3.1 Upto 5% Zone I to III	
F.16/02/2023	Aggregate-20 mm	Grading		As per IS-383:2016	To get the 20mm graded aggregate nominal size blend
F.16/03/2023	Aggregate- 10 mm	Grading		As per IS-383:2016	20mm & 10 mm metal in 1:1 proportion.

Junior Engineer

Assistant Engineer

- Copy submitted to
- 1) Assistant Engineer, SD III, WD III, WRD, Gogol- Margao- Goa.
  - 2) The Executive Engineer, Works Division XI, WRD, Rawanfond- Goa.
  - 3) The Executive Engineer, Works Division III, WRD, Ponda- Goa.
  - 4) The Surveyor of Works, Quality Control, C.P.O., Water Resources Dept., Sinchai Bhavan, Alto Porvorim-Goa.
  - 5) Office File.