

NO: WRD /WD XI / SD III/ TECH/W.F. 14-Oct-2023/246 / 2023-24

Dated:25/11/23

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to storm water drain in Sy.No.5/3 at Zariwada, Tivrem in V.P. Tivrem - Orgao in Priol Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda - Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F. 14/11/2023						75.56		No.WRD/WDXI/SDIV/ F.CF/455/2023-24. DATED: 20-11-2023
	F. 14/12/2023	15-11-2023	22-11-2023	In Foundation	1.3.6	70 kg/cm2	71.11	72.59	
	F. 14/13/2023						71.11		
1.2	F. 14/14/2023						80.00		
	F. 14/15/2023	15-11-2023	22-11-2023	In Foundation	1.3.6	70 kg/cm2	75.56	75.56	do
	F. 14/16/2023						71.11		
2.1	F. 14/17/2023						75.56		
	F. 14/18/2023	16-11-2023	23-11-2023	In Foundation	1.3.6	70 kg/cm2	66.65	74.07	do
	F. 14/19/2023						80.00		
2.2	F. 14/20/2023						75.56		
	F. 14/21/2023	16-11-2023	23-11-2023	In Foundation	1.3.6	70 kg/cm2	71.11	74.08	do
	F. 14/22/2023						75.56		
3.1	F. 14/23/2023						80.00		
	F. 14/24/2023	17-11-2023	24-11-2023	In Foundation	1.3.6	70 kg/cm2	71.11	74.07	do
	F. 14/25/2023						71.11		
3.2	F. 14/26/2023						66.65		
	F. 14/27/2023	17-11-2023	24-11-2023	In Foundation	1.3.6	70 kg/cm2	71.11	71.11	do
	F. 14/28/2023						75.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER