

NO.WRD/WDXI/SDIII/TECH/W.F.06/2024/2024-25/ 249

. Dated:-23/12/24

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Urgent protection for nallah near the house of Dattatray Devari at Deulwada in V.P. Borim of Shiroda Constituency.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

**28 days.**

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.06/36/2024						231.11		No. WRD/WD XI/ SD IV/ W.F 495/415/2024-25. <b>DATED: 14-11-2024.</b>
	F.06/37/2024	7/11/2024	5/12/2024	Foundation	1.2.4	210 kg/cm2	231.11	229.63	
	F.06/38/2024						226.67		
1.2	F.06/39/2024						235.56		do
	F.06/40/2024	7/11/2024	5/12/2024	Foundation	1.2.4	210 kg/cm2	222.22	226.67	
	F.06/41/2024						222.22		
2.1	F.06/42/2024						231.11		do
	F.06/43/2024	8/11/2024	6/12/2024	Foundation	1.2.4	210 kg/cm2	231.11	228.15	
	F.06/44/2024						222.22		
2.2	F.06/45/2024						235.56		do
	F.06/46/2024	8/11/2024	6/12/2024	Foundation	1.2.4	210 kg/cm2	213.33	226.67	
	F.06/47/2024						231.11		
3.1	F.06/48/2024						240.00		do
	F.06/49/2024	10/11/2024	8/12/2024	1st Lift	1.2.4	210 kg/cm2	217.78	228.15	
	F.06/50/2024						226.67		
3.2	F.06/51/2024						226.67		do
	F.06/52/2024	10/11/2024	8/12/2024	1st Lift	1.2.4	210 kg/cm2	226.67	229.63	
	F.06/53/2024						235.56		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Urgent protection for nallah near the house of Dattatray Devari at Deulwada in V.P. Borim of Shiroda Constituency.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.1	F.06/54/2024						226.67		No. WRD/WD XI/ SD IV/ W.F 495/ <b>415</b> /2024-25. <b>DATED: 14-11-2024.</b>
	F.06/55/2024	11/11/2024	9/12/2024	1st Lift	1.2.4	210 kg/cm2	235.56	229.63	
	F.06/56/2024						226.67		
4.2	F.06/57/2024						231.11		
	F.06/58/2024	11/11/2024	9/12/2024	1st Lift	1.2.4	210 kg/cm2	231.11	226.67	do
	F.06/59/2024						217.78		
5.1	F.06/60/2024						235.56		
	F.06/61/2024	13-11-2024	11/12/2024	2nd Lift	1.2.4	210 kg/cm2	231.11	228.15	do
	F.06/62/2024						217.78		
5.2	F.06/63/2024						231.11		
	F.06/64/2024	13-11-2024	11/12/2024	2nd Lift	1.2.4	210 kg/cm2	226.67	226.67	do
	F.06/65/2024						222.22		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**