

NO: WRD /WD XI / SD III/ TECH/W.F. 03- Oct- 023/251 / 2023-24

Dated:30/11/23

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement and Development of nallah / waterways at Kamral in Curchorem Constituency (2nd Call).

**SAMPLE SENT BY:** AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.03/07/2023						231.11		No. WRD/WD XII/SD V/ F.70/224/2023-24. <b>DATED: 07-11-2023</b>
	F.03/08/2023	23-10-2023	20-11-2023	Foundation (L.H.S)	1.2.4	210 kg/cm2	213.33	223.70	
	F.03/09/2023						226.67		
1.2	F.03/10/2023						231.11		do
	F.03/11/2023	23-10-2023	20-11-2023	Foundation (L.H.S)	1.2.4	210 kg/cm2	226.67	226.67	
	F.03/12/2023						222.22		
2.1	F.03/13/2023						235.56		do
	F.03/14/2023	24-10-2023	21-11-2023	Foundation (L.H.S)	1.2.4	210 kg/cm2	231.11	229.63	
	F.03/09/2023						222.22		
2.2	F.03/10/2023						226.67		do
	F.03/11/2023	24-10-2023	21-11-2023	Foundation (L.H.S)	1.2.4	210 kg/cm2	231.11	228.15	
	F.03/12/2023						226.67		
3.1	F.03/13/2023						226.67		do
	F.03/14/2023	25-10-2023	22-11-2023	1st Lift (L.H.S)	1.2.4	210 kg/cm2	240.00	228.15	
	F.03/15/2023						217.78		
3.2	F.03/16/2023						231.11		do
	F.03/17/2023	25-10-2023	22-11-2023	1st Lift (L.H.S)	1.2.4	210 kg/cm2	226.67	226.67	
	F.03/18/2023						222.22		
4.1	F.03/19/2023						235.56		do
	F.03/20/2023	26-10-2023	23-11-2023	Foundation (L.H.S)	1.2.4	210 kg/cm2	226.67	226.67	
	F.03/21/2023						217.78		
4.2	F.03/22/2023						231.11		do
	F.03/23/2023	26-10-2023	23-11-2023	Foundation (L.H.S)	1.2.4	210 kg/cm2	222.22	226.67	
	F.03/24/2023						226.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

## SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Improvement and Development of nallah / waterways at Kamral in Curchorem Constituency (2nd Call).

**SAMPLE SENT BY:** AE, SD V, WD XII, WRD, Quepem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.03/25/2023						231.11		No. WRD/WD XII/SD V/ F.70/224/2023-24. <b>DATED: 07-11-2023</b>
	F.03/26/2023	27-10-2023	24-11-2023	Foundation (L.H.S)	1.2.4	210 kg/cm2	231.11	228.15	
	F.03/27/2023						222.22		
5.2	F.03/28/2023						231.11		do
	F.03/29/2023	27-10-2023	24-11-2023	Foundation (L.H.S)	1.2.4	210 kg/cm2	217.78	226.67	
	F.03/30/2023						231.11		
6.1	F.03/31/2023						226.67		do
	F.03/32/2023	28-10-2023	25-11-2023	1st Lift (L.H.S)	1.2.4	210 kg/cm2	222.22	226.67	
	F.03/33/2023						231.11		
6.2	F.03/34/2023						217.78		do
	F.03/35/2023	28-10-2023	25-11-2023	1st Lift (L.H.S)	1.2.4	210 kg/cm2	235.56	226.67	
	F.03/36/2023						226.67		
7.1	F.03/37/2023						231.11		do
	F.03/38/2023	30-10-2023	27-11-2023	Foundation (L.H.S)	1.2.4	210 kg/cm2	240.00	232.59	
	F.03/39/2023						226.67		
7.2	F.03/40/2023						235.56		do
	F.03/41/2023	30-10-2023	27-11-2023	Foundation (L.H.S)	1.2.4	210 kg/cm2	231.11	231.11	
	F.03/42/2023						226.67		
8.1	F.03/43/2023						244.44		do
	F.03/44/2023	31-10-2023	28-11-2023	Foundation (L.H.S)	1.2.4	210 kg/cm2	222.22	232.59	
	F.03/45/2023						231.11		
8.2	F.03/46/2023						235.56		do
	F.03/47/2023	31-10-2023	28-11-2023	Foundation (L.H.S)	1.2.4	210 kg/cm2	231.11	229.63	
	F.03/48/2023						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Improvement and Development of nallah / waterways at Kamral in Curchorem Constituency (2nd Call).

**SAMPLE SENT BY:** AE, SD V, WD XII, WRD, Quepem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
9.1	F.03/49/2023						235.56		No. WRD/WD XII/SD V/ F.70/224/2023-24. <b>DATED: 07-11-2023</b>
	F.03/50/2023	1/11/2023	29-11-2023	1st Lift (L.H.S)	1.2.4	210 kg/cm <sup>2</sup>	226.67	223.71	
	F.03/51/2023						208.89		
9.2	F.03/52/2023						222.22		do
	F.03/53/2023	1/11/2023	29-11-2023	1st Lift (L.H.S)	1.2.4	210 kg/cm <sup>2</sup>	226.67	225.19	
	F.03/54/2023						226.67		
10.1	F.03/55/2023						231.11		do
	F.03/56/2023	2/11/2023	30-11-2023	1st Lift (L.H.S)	1.2.4	210 kg/cm <sup>2</sup>	222.22	226.67	
	F.03/57/2023						226.67		
10.2	F.03/58/2023						226.67		do
	F.03/59/2023	2/11/2023	30-11-2023	1st Lift (L.H.S)	1.2.4	210 kg/cm <sup>2</sup>	226.67	228.15	
	F.03/60/2023						231.11		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**NO: WRD /WD XI / SD III/ TECH/W.F. 03- Oct- 023/271 / 2023-24**

**Dated:18/12/23**

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement and Development of nallah / waterways at Kamral in Curchorem Constituency (2nd Call).

**SAMPLE SENT BY:** AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
11.1	F.03/79/2023						226.67		No. WRD/SD V/WD XII/ F.70/ <b>233</b> /2023-24. <b>DATED: 21-11-2023</b>
	F.03/80/2023	3/11/2023	1/12/2023	1st Lift (LHS)	1.2.4	210 kg/cm2	222.22	225.19	
	F.03/81/2023						226.67		
11.2	F.03/82/2023						217.78		do
	F.03/83/2023	3/11/2023	1/12/2023	1st Lift (LHS)	1.2.4	210 kg/cm2	226.67	225.19	
	F.03/84/2023						231.11		
12.1	F.03/85/2023						226.67		do
	F.03/86/2023	4/11/2023	2/12/2023	2nd Lift (LHS)	1.2.4	210 kg/cm2	222.22	228.15	
	F.03/87/2023						235.56		
12.2	F.03/88/2023						231.11		do
	F.03/89/2023	4/11/2023	2/12/2023	2nd Lift (LHS)	1.2.4	210 kg/cm2	235.56	229.63	
	F.03/90/2023						222.22		
13.1	F.03/91/2023						226.67		do
	F.03/92/2023	7/11/2023	5/12/2023	2nd Lift (LHS)	1.2.4	210 kg/cm2	240.00	226.67	
	F.03/93/2023						213.33		
13.2	F.03/94/2023						231.11		do
	F.03/95/2023	7/11/2023	5/12/2023	2nd Lift (LHS)	1.2.4	210 kg/cm2	226.67	225.19	
	F.03/96/2023						217.78		
14.1	F.03/97/2023						231.11		do
	F.03/98/2023	8/11/2023	6/12/2023	2nd Lift (LHS)	1.2.4	210 kg/cm2	226.67	222.22	
	F.03/99/2023						208.87		
14.2	F.03/100/2023						226.67		do
	F.03/101/2023	8/11/2023	6/12/2023	2nd Lift (LHS)	1.2.4	210 kg/cm2	226.67	225.19	
	F.03/102/2023						222.22		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement and Development of nallah / waterways at Kamral in Curchorem Constituency (2nd Call).

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
15.1	F.03/103/2023						235.56		No. WRD/SD V/WD XII/ F.70/233/2023-24. <b>DATED: 21-11-2023</b>
	F.03/104/2023	9/11/2023	7/12/2023	Foundation (RHS)	1.2.4	210 kg/cm2	217.78	228.15	
	F.03/105/2023						231.11		
15.2	F.03/106/2023						226.67		
	F.03/107/2023	9/11/2023	7/12/2023	Foundation (RHS)	1.2.4	210 kg/cm2	231.11	226.67	do
	F.03/108/2023						222.22		
16.1	F.03/109/2023						240.00		
	F.03/110/2023	10/11/2023	8/12/2023	Foundation (RHS)	1.2.4	210 kg/cm2	222.22	231.11	do
	F.03/111/2023						231.11		
16.2	F.03/112/2023						235.56		
	F.03/113/2023	10/11/2023	8/12/2023	Foundation (RHS)	1.2.4	210 kg/cm2	231.11	229.63	do
	F.03/114/2023						222.22		
17.1	F.03/115/2023						226.67		
	F.03/116/2023	11/11/2023	11/12/2023	1st Lift (RHS)	1.2.4	210 kg/cm2	217.78	223.71	do
	F.03/117/2023						226.67		
17.2	F.03/118/2023						222.22		
	F.03/119/2023	11/11/2023	11/12/2023	1st Lift (RHS)	1.2.4	210 kg/cm2	226.67	225.19	do
	F.03/120/2023						226.67		
18.1	F.03/121/2023						244.44		
	F.03/122/2023	14-11-2023	12/12/2023	Foundation (RHS)	1.2.4	210 kg/cm2	231.11	231.11	do
	F.03/123/2023						217.78		
18.2	F.03/124/2023						226.67		
	F.03/125/2023	14-11-2023	12/12/2023	Foundation (RHS)	1.2.4	210 kg/cm2	231.11	231.11	do
	F.03/126/2023						235.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement and Development of nallah / waterways at Kamral in Curchorem Constituency (2nd Call).

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
19	F.03/126/2023						231.11		No. WRD/SD V/WD XII/ F.70/233/2023-24. <b>DATED: 21-11-2023</b>
	F.03/127/2023	15-11-2023	13-12-2023	Foundation (R.H.S)	1.2.4	210 kg/cm2	208.89	226.67	
	F.03/128/2023						240.00		
20	F.03/129/2023						231.11		
	F.03/130/2023	16-11-2023	14-12-2023	Foundation (R.H.S)	1.2.4	210 kg/cm2	235.56	229.63	do
	F.03/131/2023						222.22		
21	F.03/132/2023						235.56		
	F.03/133/2023	17-11-2023	15-12-2023	1st Lift (R.H.S)	1.2.4	210 kg/cm2	222.22	228.15	do
	F.03/134/2023						226.67		
22	F.03/135/2023						226.67		
	F.03/136/2023	18-11-2023	16-12-2023	1st Lift (R.H.S)	1.2.4	210 kg/cm2	226.67	229.63	do
	F.03/137/2023						235.56		
23	F.03/138/2023						240.00		
	F.03/139/2023	19-11-2023	17-12-2023	1st Lift & 2nd Lift (R.H.S)	1.2.4	210 kg/cm2	213.33	228.15	do
	F.03/140/2023						231.11		
24	F.03/141/2023						226.67		
	F.03/142/2023	20-11-2023	18-12-2023	2nd Lift (R.H.S)	1.2.4	210 kg/cm2	231.11	229.63	do
	F.03/143/2023						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER